

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P179799

Luminaire Tested: **LDA6A55840D010TE LARH30NF 6LFC1H**

Issue Date: 3/3/2020

**Test Information**

Test Method: LM-41-14  
Report Number: P179799  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P26682)  
Test Lab: INNOVATION CENTER-P2  
Issue Date: 3/3/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: io LED  
Catalog Number: LDA6A55840D010TE LARH30NF 6LFC1H  
Description: PORTFOLIO 6" Flat Cone, Self-flanged, 30° Narrow Flood  
Light Source: (1) HIGH LUMEN LED 80CRI / 4000K CCT  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 5531.7 lumens  
Efficiency: N/A  
Efficacy: 90.7 lumens/watt  
Spacing Criteria (0/90/45): 0.58 / 0.58 / 0.55  
Luminous Opening: Circular (Dia: 0.5' x H: 0')  
CIE Type: Direct


Input Watts (W): 61  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P179799

CATALOG NUMBER: LDA6A55840D010TE LARH30NF 6LFC1H

### Luminous Intensity Polar Plot





TEST NUMBER: P179799

CATALOG NUMBER: LDA6A55840D010TE LARH30NF 6LFC1H

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

|     |     |     |     |     |     |     |     |     |     |     |     |  |     |     |     |  |     |
|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--|-----|-----|-----|--|-----|
| RF  | 20  |     |     |     | 20  |     |     |     | 20  |     |     |  | 20  |     |     |  | 20  |
| RC  | 80  |     |     |     | 70  |     |     |     | 50  |     |     |  | 30  |     |     |  | 10  |
| RW  | 70  | 50  | 30  | 10  | 70  | 50  | 30  | 10  | 50  | 30  | 10  |  | 50  | 30  | 10  |  | 50  |
| RCR |     |     |     |     |     |     |     |     |     |     |     |  |     |     |     |  |     |
| 0   | 119 | 119 | 119 | 119 | 116 | 116 | 116 | 116 | 111 | 111 | 111 |  | 106 | 106 | 106 |  | 102 |
| 1   | 115 | 113 | 111 | 109 | 112 | 110 | 109 | 107 | 106 | 105 | 104 |  | 103 | 102 | 101 |  | 99  |
| 2   | 111 | 107 | 104 | 101 | 109 | 105 | 103 | 100 | 102 | 100 | 98  |  | 99  | 98  | 96  |  | 97  |
| 3   | 107 | 102 | 98  | 95  | 105 | 101 | 97  | 95  | 98  | 95  | 93  |  | 96  | 94  | 92  |  | 94  |
| 4   | 103 | 98  | 94  | 90  | 102 | 97  | 93  | 90  | 95  | 91  | 89  |  | 93  | 90  | 88  |  | 91  |
| 5   | 100 | 94  | 89  | 86  | 99  | 93  | 89  | 86  | 91  | 88  | 85  |  | 90  | 87  | 84  |  | 88  |
| 6   | 97  | 90  | 86  | 83  | 96  | 89  | 85  | 82  | 88  | 84  | 82  |  | 87  | 84  | 81  |  | 86  |
| 7   | 94  | 87  | 82  | 79  | 93  | 86  | 82  | 79  | 85  | 81  | 79  |  | 84  | 81  | 78  |  | 83  |
| 8   | 91  | 84  | 79  | 76  | 90  | 83  | 79  | 76  | 82  | 79  | 76  |  | 81  | 78  | 76  |  | 81  |
| 9   | 88  | 81  | 77  | 74  | 87  | 80  | 76  | 73  | 80  | 76  | 73  |  | 79  | 75  | 73  |  | 78  |
| 10  | 85  | 78  | 74  | 71  | 85  | 78  | 74  | 71  | 77  | 73  | 71  |  | 76  | 73  | 71  |  | 76  |

**AVERAGE LUMINANCE (cd/sqm):**

|     |        |
|-----|--------|
|     | 0°     |
| 0°  | 876317 |
| 5°  | 835839 |
| 10° | 750726 |
| 15° | 568590 |
| 20° | 338211 |
| 25° | 184801 |
| 30° | 42032  |
| 35° | 3982   |
| 40° | 1617   |
| 45° | 799    |
| 50° | 529    |
| 55° | 487    |
| 60° | 340    |
| 65° | 402    |
| 70° | 337    |
| 75° | 212    |
| 80° | 316    |
| 85° | 0      |



TEST NUMBER: P179799

CATALOG NUMBER: LDA6A55840D010TE LARH30NF 6LFC1H

**ZONAL LUMENS:**

| Zone      | Lumens | % Fixture |
|-----------|--------|-----------|
| 0°-10°    | 1393.9 | 25.2      |
| 10°-20°   | 2682.9 | 48.5      |
| 20°-30°   | 1334.3 | 24.1      |
| 30°-40°   | 103.2  | 1.9       |
| 40°-50°   | 9.2    | 0.2       |
| 50°-60°   | 4.2    | 0.1       |
| 60°-70°   | 2.7    | 0.0       |
| 70°-80°   | 1.2    | 0.0       |
| 80°-90°   | 0.1    | 0.0       |
| 90°-100°  | 0.0    | 0.0       |
| 100°-110° | 0.0    | 0.0       |
| 110°-120° | 0.0    | 0.0       |
| 120°-130° | 0.0    | 0.0       |
| 130°-140° | 0.0    | 0.0       |
| 140°-150° | 0.0    | 0.0       |
| 150°-160° | 0.0    | 0.0       |
| 160°-170° | 0.0    | 0.0       |
| 170°-180° | 0.0    | 0.0       |
| 0°-30°    | 5411.1 | 97.8      |
| 0°-40°    | 5514.3 | 99.7      |
| 0°-60°    | 5527.7 | 99.9      |
| 0°-90°    | 5531.7 | 100.0     |
| 90°-120°  | 0.0    | 0.0       |
| 90°-150°  | 0.0    | 0.0       |
| 90°-180°  | 0.0    | 0.0       |
| 0°-180°   | 5531.7 | 100.0     |

**CANDELA DISTRIBUTION:**

|     | 0°    | Flux |
|-----|-------|------|
| 0°  | 15985 |      |
| 5°  | 15189 | ###  |
| 15° | 10018 | 2683 |
| 25° | 3055  | 1334 |
| 35° | 60    | 103  |
| 45° | 10    | 9    |
| 55° | 5     | 4    |
| 65° | 3     | 3    |
| 75° | 1     | 1    |
| 85° | 0     | 0    |
| 90° | 0     |      |



TEST NUMBER: P179799

CATALOG NUMBER: LDA6A55840D010TE LARH30NF 6LFC1H

**CANDELA DISTRIBUTION (FULL):**

|       | 0°      |
|-------|---------|
| 0°    | 15985.3 |
| 2.5°  | 15669.2 |
| 5°    | 15188.9 |
| 7.5°  | 14389.4 |
| 10°   | 13486.3 |
| 12.5° | 12113.2 |
| 15°   | 10018.5 |
| 17.5° | 7737.1  |
| 20°   | 5797.4  |
| 22.5° | 4252.9  |
| 25°   | 3055.2  |
| 27.5° | 1601.0  |
| 30°   | 664.0   |
| 32.5° | 263.8   |
| 35°   | 59.5    |
| 37.5° | 34.9    |
| 40°   | 22.6    |
| 42.5° | 15.4    |
| 45°   | 10.3    |
| 47.5° | 8.2     |
| 50°   | 6.2     |
| 52.5° | 5.1     |
| 55°   | 5.1     |
| 57.5° | 4.1     |
| 60°   | 3.1     |
| 62.5° | 3.1     |
| 65°   | 3.1     |
| 67.5° | 2.1     |
| 70°   | 2.1     |
| 72.5° | 1.0     |
| 75°   | 1.0     |
| 77.5° | 1.0     |
| 80°   | 1.0     |
| 82.5° | 0.0     |
| 85°   | 0.0     |
| 87.5° | 0.0     |
| 90°   | 0.0     |



Report Generated By E9808895 / USPTCWHP6082093







— 0°-180°







(END OF REPORT)