

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P205072

Luminaire Tested: **LE_6B10D010 EC6B10209035 6LBMLI1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P205072
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LE_6B10D010 EC6B10209035 6LBML1
Description: PORTFOLIO 6 INCH 50 DEGREE CUTOFF RECESSED DOWNLIGHT
MEDIUM DISTRIBUTION WITH SPECULAR CLEAR TRIM
WATTAGE D010TR-10.05 W DE010-10.58 W D5LT-10.2 W DMX-10.6 W DL2-11.8 W
DL3-11.1 W DLE-11.39 W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1030.6 lumens
Efficiency: N/A
Efficacy: 104.1 lumens/watt
Spacing Criteria (0/90/45): 0.85 / 0.85 / 0.85
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 9.9
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P205072

CATALOG NUMBER: LE_6B10D010 EC6B10209035 6LBMLI1

Luminous Intensity Polar Plot





TEST NUMBER: P205072

CATALOG NUMBER: LE_6B10D010 EC6B10209035 6LBMLI1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	114	111	109	106	111	109	107	105	105	103	101		101	100	98		98
2	108	103	100	96	106	102	98	95	99	96	93		96	93	91		93
3	103	97	92	88	101	95	91	87	93	89	86		90	87	85		88
4	98	91	85	81	96	89	84	81	87	83	80		85	82	79		83
5	93	85	79	75	91	84	79	75	82	78	74		81	77	73		79
6	89	80	74	70	87	79	74	70	78	73	69		76	72	69		75
7	84	75	69	65	83	75	69	65	73	68	65		72	68	64		71
8	80	71	65	61	79	70	65	61	69	64	61		68	64	60		67
9	77	67	61	57	75	67	61	57	66	61	57		65	60	57		64
10	73	64	58	54	72	63	58	54	62	57	54		62	57	54		61

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P205072

CATALOG NUMBER: LE_6B10D010 EC6B10209035 6LBMLI1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	118.8	11.5
10°-20°	295.8	28.7
20°-30°	343.8	33.4
30°-40°	210.6	20.4
40°-50°	52.3	5.1
50°-60°	6.1	0.6
60°-70°	2.3	0.2
70°-80°	0.9	0.1
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	758.4	73.6
0°-40°	969.0	94.0
0°-60°	1027.4	99.7
0°-90°	1030.6	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1030.6	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1290	
5°	1272	119
15°	1062	296
25°	761	344
35°	330	211
45°	58	52
55°	5	6
65°	3	2
75°	1	1
85°	0	0
90°	0	



TEST NUMBER: P205072

CATALOG NUMBER: LE_6B10D010 EC6B10209035 6LBMLI1

CANDELA DISTRIBUTION (FULL):

	0°
0°	1289.6
2.5°	1288.4
5°	1272.5
7.5°	1238.2
10°	1192.1
12.5°	1131.4
15°	1061.5
17.5°	986.4
20°	912.5
22.5°	838.6
25°	760.9
27.5°	671.2
30°	568.4
32.5°	448.4
35°	329.6
37.5°	232.1
40°	158.2
42.5°	98.9
45°	58.0
47.5°	33.0
50°	17.1
52.5°	7.9
55°	5.2
57.5°	4.0
60°	4.0
62.5°	2.6
65°	2.6
67.5°	1.4
70°	1.4
72.5°	1.4
75°	1.4
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)