

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P202600

Luminaire Tested: **LE_6B10D010 EC6B10209035 6LBMWMH1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P202600
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LE_6B10D010 EC6B10209035 6LBMWMH1
Description: PORTFOLIO 6 INCH 50 DEGREE CUTOFF RECESSED DOWNLIGHT
MEDIUM DISTRIBUTION WITH WARM HAZE TRIM
WATTAGE D010TR-10.05 W DE010-10.58 W D5LT-10.2 W DMX-10.6 W DL2-11.8 W
DL3-11.1 W DLE-11.39 W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 903.6 lumens
Efficiency: N/A
Efficacy: 91.3 lumens/watt
Spacing Criteria (0/90/45): 0.9 / 0.9 / 0.89
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 9.9
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P202600

CATALOG NUMBER: LE_6B10D010 EC6B10209035 6LBMWMH1

Luminous Intensity Polar Plot





TEST NUMBER: P202600

CATALOG NUMBER: LE_6B10D010 EC6B10209035 6LBMWMH1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20
RC	80					70					50					30					10
RW	70	50	30	10		70	50	30	10		50	30	10		50	30	10		50	30	10
RCR																					
0	119	119	119	119		116	116	116	116		111	111	111		106	106	106		102	102	102
1	113	111	108	106		111	108	106	104		104	103	101		101	99	98		97	96	95
2	108	103	99	95		105	101	97	94		98	95	92		95	92	90		92	90	88
3	102	95	90	86		100	94	89	86		91	88	84		89	86	83		87	84	82
4	97	89	83	79		95	88	83	79		86	81	78		84	80	77		82	79	76
5	92	83	77	73		90	82	77	73		80	76	72		79	75	71		77	74	71
6	87	78	72	67		85	77	71	67		76	71	67		74	70	66		73	69	66
7	83	73	67	63		81	72	67	63		71	66	62		70	65	62		69	65	61
8	78	69	63	58		77	68	62	58		67	62	58		66	61	58		65	61	58
9	75	65	59	55		73	64	59	55		63	58	54		62	58	54		62	57	54
10	71	61	55	51		70	61	55	51		60	55	51		59	54	51		58	54	51

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P202600

CATALOG NUMBER: LE_6B10D010 EC6B10209035 6LBMWMH1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	92.2	10.2
10°-20°	236.7	26.2
20°-30°	290.8	32.2
30°-40°	199.4	22.1
40°-50°	64.1	7.1
50°-60°	13.0	1.4
60°-70°	5.1	0.6
70°-80°	1.9	0.2
80°-90°	0.3	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	619.7	68.6
0°-40°	819.1	90.7
0°-60°	896.2	99.2
0°-90°	903.6	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	903.6	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1005	
5°	986	92
15°	847	237
25°	642	291
35°	318	199
45°	76	64
55°	13	13
65°	5	5
75°	2	2
85°	0	0
90°	0	



TEST NUMBER: P202600

CATALOG NUMBER: LE_6B10D010 EC6B10209035 6LBMWMH1

CANDELA DISTRIBUTION (FULL):

	0°
0°	1004.8
2.5°	998.6
5°	985.6
7.5°	961.1
10°	928.1
12.5°	887.5
15°	846.9
17.5°	801.8
20°	751.9
22.5°	699.8
25°	641.5
27.5°	577.1
30°	495.9
32.5°	406.2
35°	318.1
37.5°	237.6
40°	170.9
42.5°	116.5
45°	75.9
47.5°	46.8
50°	28.4
52.5°	17.6
55°	13.0
57.5°	10.0
60°	7.6
62.5°	6.1
65°	5.4
67.5°	3.9
70°	3.1
72.5°	2.2
75°	1.5
77.5°	1.5
80°	0.8
82.5°	0.8
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)