

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P202908

Luminaire Tested: **LE_6B10D010 EC6B10209035 6LBWGPH1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P202908
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LE_6B10D010 EC6B10209035 6LBWGPH1
Description: PORTFOLIO 6 INCH 60 DEGREE CUTOFF RECESSED DOWNLIGHT
WIDE DISTRIBUTIONWITH GRAPHITE HAZE TRIM
WATTAGE D010TR-10.05 W DE010-10.58 W D5LT-10.2 W DMX-10.6 W DL2-11.8 W
DL3-11.1 W DLE-11.39 W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 766.6 lumens
Efficiency: N/A
Efficacy: 77.4 lumens/watt
Spacing Criteria (0/90/45): 1.11 / 1.11 / 1.11
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 9.9
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P202908

CATALOG NUMBER: LE_6B10D010 EC6B10209035 6LBWGPH1

Luminous Intensity Polar Plot





TEST NUMBER: P202908

CATALOG NUMBER: LE_6B10D010 EC6B10209035 6LBWGPH1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	112	109	106	104	110	107	104	102	103	101	99		99	98	96		96
2	106	100	95	91	103	98	94	90	95	91	88		92	89	86		89
3	99	91	85	81	97	90	84	80	87	82	79		85	81	77		82
4	93	84	77	72	91	82	76	72	80	75	71		78	74	70		76
5	87	77	70	65	85	76	69	65	74	68	64		72	67	63		71
6	81	71	64	59	80	70	63	59	68	62	58		67	62	58		65
7	76	65	58	53	75	65	58	53	63	57	53		62	57	53		61
8	72	61	54	49	70	60	53	49	59	53	49		58	52	48		57
9	68	57	50	45	66	56	49	45	55	49	45		54	48	45		53
10	64	53	46	42	63	52	46	42	51	45	41		51	45	41		50

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P202908

CATALOG NUMBER: LE_6B10D010 EC6B10209035 6LBWGPH1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	49.1	6.4
10°-20°	137.6	18.0
20°-30°	196.9	25.7
30°-40°	196.3	25.6
40°-50°	125.0	16.3
50°-60°	46.1	6.0
60°-70°	11.5	1.5
70°-80°	3.5	0.5
80°-90°	0.6	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	383.7	50.0
0°-40°	580.0	75.7
0°-60°	751.0	98.0
0°-90°	766.6	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	766.6	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	521	
5°	518	49
15°	489	138
25°	430	197
35°	319	196
45°	161	125
55°	49	46
65°	10	12
75°	3	3
85°	0	1
90°	0	



TEST NUMBER: P202908

CATALOG NUMBER: LE_6B10D010 EC6B10209035 6LBWGPH1

CANDELA DISTRIBUTION (FULL):

	0°
0°	521.0
2.5°	521.0
5°	518.4
7.5°	513.1
10°	506.5
12.5°	498.6
15°	489.4
17.5°	477.5
20°	464.4
22.5°	449.9
25°	430.0
27.5°	408.9
30°	381.2
32.5°	352.2
35°	319.2
37.5°	279.6
40°	238.8
42.5°	199.1
45°	160.9
47.5°	126.6
50°	95.0
52.5°	69.9
55°	48.8
57.5°	31.6
60°	21.1
62.5°	14.5
65°	10.5
67.5°	7.9
70°	6.6
72.5°	4.0
75°	2.6
77.5°	2.6
80°	1.4
82.5°	1.4
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)