

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P205491

Luminaire Tested: **LE_6B15D010 EC6B10209035 6LBMGPH1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P205491
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LE_6B15D010 EC6B10209035 6LBMGPH1
Description: PORTFOLIO 6 INCH 50 DEGREE CUTOFF RECESSED DOWNLIGHT
MEDIUM DISTRIBUTION WITH GRAPHITE HAZE TRIM
WATTAGE D010TR-14.39 W DE010-14.29 W D5LT-14.34 W DMX-14.46 W DL2-15.8 W
DL3-15.28 W DLE-15.432 W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 885.9 lumens
Efficiency: N/A
Efficacy: 61.9 lumens/watt
Spacing Criteria (0/90/45): 0.94 / 0.94 / 0.91
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 14.3
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P205491

CATALOG NUMBER: LE_6B15D010 EC6B10209035 6LBMGPH1

Luminous Intensity Polar Plot





TEST NUMBER: P205491

CATALOG NUMBER: LE_6B15D010 EC6B10209035 6LBMGPH1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	113	110	108	105	111	108	106	104	104	102	101		100	99	98		97
2	107	102	98	94	105	100	97	93	97	94	91		94	92	89		91
3	102	95	90	85	99	93	89	85	91	87	83		88	85	82		86
4	96	88	82	78	94	87	82	77	85	80	77		83	79	76		81
5	91	82	76	72	89	81	76	71	79	74	71		78	73	70		76
6	86	77	71	66	85	76	70	66	74	69	65		73	68	65		72
7	82	72	66	61	80	71	65	61	70	65	61		69	64	60		68
8	77	68	61	57	76	67	61	57	66	60	57		65	60	56		64
9	74	64	57	53	72	63	57	53	62	57	53		61	56	53		60
10	70	60	54	50	69	59	54	50	59	53	50		58	53	49		57

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P205491

CATALOG NUMBER: LE_6B15D010 EC6B10209035 6LBMGPH1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	84.8	9.6
10°-20°	220.0	24.8
20°-30°	280.3	31.6
30°-40°	198.2	22.4
40°-50°	72.3	8.2
50°-60°	20.1	2.3
60°-70°	7.3	0.8
70°-80°	2.6	0.3
80°-90°	0.2	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	585.2	66.1
0°-40°	783.3	88.4
0°-60°	875.7	98.9
0°-90°	885.9	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	885.9	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	923	
5°	907	85
15°	784	220
25°	622	280
35°	315	198
45°	88	72
55°	22	20
65°	7	7
75°	2	3
85°	0	0
90°	0	



TEST NUMBER: P205491

CATALOG NUMBER: LE_6B15D010 EC6B10209035 6LBMGPH1

CANDELA DISTRIBUTION (FULL):

0°	
0°	923.1
2.5°	919.5
5°	907.0
7.5°	881.9
10°	855.1
12.5°	819.2
15°	783.5
17.5°	747.8
20°	712.0
22.5°	669.0
25°	622.5
27.5°	558.1
30°	486.6
32.5°	400.8
35°	314.9
37.5°	239.8
40°	175.2
42.5°	127.0
45°	87.6
47.5°	59.0
50°	39.4
52.5°	26.9
55°	21.5
57.5°	16.1
60°	12.5
62.5°	9.0
65°	7.1
67.5°	5.4
70°	3.6
72.5°	3.6
75°	1.8
77.5°	1.8
80°	1.8
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)