

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P204260

Luminaire Tested: **LE_6B15D010 EC6B10209035 6LBSWH1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P204260
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LE_6B15D010 EC6B10209035 6LBSWH1
Description: PORTFOLIO 6 INCH SHALLOW RECESSED DOWNLIGHT
SHALLOW DISTRIBUTION WITH WHEAT TRIM
WATTAGE D010TR-14.39 W DE010-14.29 W D5LT-14.34 W DMX-14.46 W DL2-15.8 W
DL3-15.28 W DLE-15.432 W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1662.5 lumens
Efficiency: N/A
Efficacy: 116.3 lumens/watt
Spacing Criteria (0/90/45): 0.94 / 0.94 / 1.08
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 14.3
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P204260

CATALOG NUMBER: LE_6B15D010 EC6B10209035 6LBSWH1

Luminous Intensity Polar Plot





TEST NUMBER: P204260

CATALOG NUMBER: LE_6B15D010 EC6B10209035 6LBSWH1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					0
RW	70	50	30	10	70	50	30	10		50	30	10			50	30	10			0
RCR																				
0	119	119	119	119	116	116	116	116		111	111	111			106	106	106			100
1	111	107	104	101	108	105	102	99		101	98	96			97	95	93			89
2	103	96	90	85	100	94	89	84		91	86	83			87	84	81			77
3	95	86	79	73	93	84	78	73		82	76	72			79	74	70			67
4	88	77	70	64	86	76	69	63		74	68	63			72	66	62			59
5	81	70	62	56	79	69	62	56		67	60	55			65	59	55			52
6	76	64	56	50	74	63	55	50		61	54	49			60	54	49			47
7	71	58	51	45	69	58	50	45		56	49	45			55	49	44			42
8	66	54	46	41	65	53	46	41		52	45	40			51	45	40			38
9	62	50	42	37	61	49	42	37		48	41	37			47	41	37			35
10	58	46	39	34	57	46	39	34		45	38	34			44	38	34			32

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P204260

CATALOG NUMBER: LE_6B15D010 EC6B10209035 6LBSWH1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	91.4	5.5
10°-20°	236.7	14.2
20°-30°	309.6	18.6
30°-40°	327.8	19.7
40°-50°	305.8	18.4
50°-60°	231.6	13.9
60°-70°	125.4	7.5
70°-80°	33.7	2.0
80°-90°	0.5	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	637.7	38.4
0°-40°	965.6	58.1
0°-60°	1502.9	90.4
0°-90°	1662.5	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1662.5	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	992	
5°	977	91
15°	846	237
25°	673	310
35°	524	328
45°	398	306
55°	260	232
65°	126	125
75°	29	34
85°	0	0
90°	0	



TEST NUMBER: P204260

CATALOG NUMBER: LE_6B15D010 EC6B10209035 6LBSWH1

CANDELA DISTRIBUTION (FULL):

	0°
0°	991.5
2.5°	987.9
5°	977.0
7.5°	953.2
10°	922.4
12.5°	886.0
15°	846.0
17.5°	800.5
20°	760.5
22.5°	715.0
25°	673.1
27.5°	631.2
30°	591.2
32.5°	556.8
35°	524.0
37.5°	491.2
40°	460.2
42.5°	429.4
45°	398.4
47.5°	363.9
50°	329.2
52.5°	294.8
55°	260.1
57.5°	223.8
60°	189.2
62.5°	156.5
65°	125.5
67.5°	96.4
70°	71.0
72.5°	49.1
75°	29.1
77.5°	12.8
80°	3.6
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)