

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P204159

Luminaire Tested: **LE_6B15D010 EC6B10209050 6LBSH1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P204159
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LE_6B15D010 EC6B10209050 6LBSH1
Description: PORTFOLIO 6 INCH SHALLOW RECESSED DOWNLIGHT
SHALLOW DISTRIBUTION WITH SEMI-SPECULAR CLEAR TRIM
WATTAGE D010TR-14.39 W DE010-14.29 W D5LT-14.34 W DMX-14.46 W DL2-15.8 W
DL3-15.28 W DLE-15.432 W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1662.8 lumens
Efficiency: N/A
Efficacy: 116.3 lumens/watt
Spacing Criteria (0/90/45): 1.06 / 1.06 / 1.17
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 14.3
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P204159

CATALOG NUMBER: LE_6B15D010 EC6B10209050 6LBSH1

Luminous Intensity Polar Plot





TEST NUMBER: P204159

CATALOG NUMBER: LE_6B15D010 EC6B10209050 6LBSH1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10		50	30	10			50	30	10			50
RCR																				
0	119	119	119	119	116	116	116	116		111	111	111			106	106	106			102
1	111	107	104	101	108	105	102	99		101	98	96			97	95	93			93
2	102	96	90	85	100	94	88	84		90	86	82			87	83	80			84
3	95	85	78	73	92	84	77	72		81	75	71			78	74	70			76
4	87	77	69	63	85	75	68	63		73	67	62			71	65	61			69
5	81	69	61	55	79	68	61	55		66	60	55			64	59	54			63
6	75	63	55	49	73	62	54	49		60	54	49			59	53	48			57
7	70	58	50	44	68	57	49	44		55	49	44			54	48	43			53
8	65	53	45	40	64	52	45	40		51	44	39			50	44	39			49
9	61	49	41	36	60	48	41	36		47	40	36			46	40	36			45
10	58	45	38	33	56	45	38	33		44	37	33			43	37	33			42

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P204159

CATALOG NUMBER: LE_6B15D010 EC6B10209050 6LBSH1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	81.5	4.9
10°-20°	221.4	13.3
20°-30°	307.5	18.5
30°-40°	335.5	20.2
40°-50°	313.0	18.8
50°-60°	237.6	14.3
60°-70°	130.1	7.8
70°-80°	35.8	2.2
80°-90°	0.5	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	610.3	36.7
0°-40°	945.9	56.9
0°-60°	1496.4	90.0
0°-90°	1662.8	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1662.8	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	870	
5°	862	81
15°	789	221
25°	668	307
35°	536	336
45°	406	313
55°	266	238
65°	130	130
75°	31	36
85°	0	0
90°	0	



TEST NUMBER: P204159

CATALOG NUMBER: LE_6B15D010 EC6B10209050 6LBSH1

CANDELA DISTRIBUTION (FULL):

	0°
0°	869.6
2.5°	869.6
5°	862.2
7.5°	851.4
10°	834.9
12.5°	812.9
15°	789.1
17.5°	759.8
20°	732.4
22.5°	699.4
25°	668.2
27.5°	637.1
30°	602.4
32.5°	569.4
35°	536.4
37.5°	503.5
40°	472.4
42.5°	439.4
45°	406.4
47.5°	373.5
50°	336.9
52.5°	302.1
55°	265.5
57.5°	230.6
60°	195.9
62.5°	161.1
65°	130.0
67.5°	100.8
70°	75.1
72.5°	51.2
75°	31.1
77.5°	14.6
80°	3.6
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)