

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: PrentaLux

Report Number: P979641

Luminaire Tested: PRLX-241-927-62L-C-U-S-WHTE-X

Issue Date: 4/3/2025

Test Information

Test Method: LM-79-2019
Report Number: P979641
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-2502-353-11)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 4/3/2025
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PrentaLux
Catalog Number: PRLX-241-927-62L-C-U-S-WHTE-X
Description: 3D PRINTED LUMINAIRE, INTEGRAL LED LIGHT ENGINE, WHITE 241 SHADE WITH CLEAR LENS
Light Source: 2700K CCT, 90 CRI LEDS
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 5070.7 lumens
Efficiency: N/A
Efficacy: 105.6 lumens/watt
Spacing Criteria (0/90/45): 1.22 / 1.22 / 1.09
Luminous Opening: Circular (Dia: 1.33' x H: 0')
CIE Type: Direct

Input Watts (W): 48
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P979641

CATALOG NUMBER: PRLX-241-927-62L-C-U-S-WHTE-X

Luminous Intensity Polar Plot



TEST NUMBER: P979641

CATALOG NUMBER: PRLX-241-927-62L-C-U-S-WHTE-X

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		0
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		100
1	111	107	103	100	108	105	101	98	100	98	95		97	94	92		88
2	103	96	90	85	100	94	89	84	91	86	83		87	84	81		77
3	95	87	80	74	93	85	79	74	82	77	73		80	75	71		68
4	89	79	71	66	87	78	71	65	75	69	65		73	68	64		61
5	83	72	64	59	81	71	64	59	69	63	58		67	62	57		55
6	78	66	59	53	76	65	58	53	64	57	52		62	56	52		50
7	73	61	54	48	71	60	53	48	59	53	48		58	52	48		45
8	69	57	49	44	67	56	49	44	55	48	44		54	48	44		42
9	65	53	46	41	63	52	45	41	51	45	40		50	44	40		38
10	61	49	42	38	60	49	42	37	48	42	37		47	41	37		36

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	24227
5°	23658
10°	22808
15°	22514
20°	22590
25°	22696
30°	22764
35°	21980
40°	8488
45°	5965
50°	5842
55°	6180
60°	6502
65°	6698
70°	6473
75°	6118
80°	5727
85°	5307

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 65°

Luminance: 6698 cd/sqm

TEST NUMBER: P979641

CATALOG NUMBER: PRLX-241-927-62L-C-U-S-WHTE-X

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	287.0	5.7
10°-20°	799.4	15.8
20°-30°	1230.2	24.3
30°-40°	1251.3	24.7
40°-50°	448.3	8.8
50°-60°	410.0	8.1
60°-70°	358.2	7.1
70°-80°	217.9	4.3
80°-90°	68.5	1.4
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2316.6	45.7
0°-40°	3567.9	70.4
0°-60°	4426.2	87.3
0°-90°	5070.7	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	5070.7	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	3143	
5°	3057	287
15°	2821	799
25°	2668	1230
35°	2336	1251
45°	547	448
55°	460	410
65°	367	358
75°	205	218
85°	60	68
90°	0	

TEST NUMBER: P979641

CATALOG NUMBER: PRLX-241-927-62L-C-U-S-WHTE-X

CANDELA DISTRIBUTION (FULL):

0°	
0°	3142.6
2.5°	3131.7
5°	3057.2
7.5°	2973.6
10°	2913.6
12.5°	2868.1
15°	2820.9
17.5°	2790.0
20°	2753.6
22.5°	2717.3
25°	2668.2
27.5°	2613.7
30°	2557.3
32.5°	2486.4
35°	2335.6
37.5°	1581.3
40°	843.4
42.5°	614.3
45°	547.1
47.5°	505.3
50°	487.1
52.5°	474.4
55°	459.8
57.5°	441.7
60°	421.7
62.5°	398.0
65°	367.2
67.5°	327.2
70°	287.2
72.5°	245.4
75°	205.4
77.5°	167.2
80°	129.0
82.5°	94.5
85°	60.0
87.5°	32.7
90°	0.0

TEST NUMBER: P979641

CATALOG NUMBER: PRLX-241-927-62L-C-U-S-WHTE-X

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	16.79	18.11	17.15	18.42	18.74	16.79	18.11	17.15	18.42	18.74
	3H	18.94	20.13	19.32	20.46	20.82	18.94	20.13	19.32	20.46	20.82
	4H	19.73	20.84	20.13	21.19	21.57	19.73	20.84	20.13	21.19	21.57
	6H	20.31	21.34	20.73	21.71	22.10	20.31	21.34	20.73	21.71	22.10
	8H	20.52	21.49	20.95	21.88	22.29	20.52	21.49	20.95	21.88	22.29
	12H	20.66	21.59	21.09	21.97	22.40	20.66	21.59	21.09	21.97	22.40
4H	2H	17.53	18.65	17.94	19.00	19.38	17.53	18.65	17.94	19.00	19.38
	3H	19.85	20.78	20.26	21.18	21.58	19.85	20.78	20.26	21.18	21.58
	4H	20.75	21.58	21.18	22.00	22.44	20.75	21.58	21.18	22.00	22.44
	6H	21.46	22.19	21.92	22.63	23.10	21.46	22.19	21.92	22.63	23.10
	8H	21.71	22.39	22.18	22.84	23.31	21.71	22.39	22.18	22.84	23.31
	12H	21.90	22.50	22.38	22.98	23.45	21.90	22.50	22.38	22.98	23.45
8H	4H	21.07	21.75	21.54	22.19	22.66	21.07	21.75	21.54	22.19	22.66
	6H	21.92	22.48	22.43	22.97	23.45	21.92	22.48	22.43	22.97	23.45
	8H	22.26	22.76	22.78	23.27	23.76	22.26	22.76	22.78	23.27	23.76
	12H	22.55	22.98	23.06	23.47	24.04	22.55	22.98	23.06	23.47	24.04
12H	4H	21.10	21.70	21.58	22.18	22.65	21.10	21.70	21.58	22.18	22.65
	6H	21.99	22.48	22.51	23.00	23.49	21.99	22.48	22.51	23.00	23.49
	8H	22.39	22.82	22.91	23.32	23.89	22.39	22.82	22.91	23.32	23.89