

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2024 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: PrentaLux

Report Number: P979932

Luminaire Tested: PRLX-242-927-LL4-F-U-S-BLAK-X

Issue Date: 4/3/2025

Test Information

Test Method: LM-79-2024
Report Number: P979932
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-2502-353-27)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 4/3/2025
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PrentaLux
Catalog Number: PRLX-242-927-LL4-F-U-S-BLAK-X
Description: 3D PRINTED LUMINAIRE, INTEGRAL LED LIGHT ENGINE, BLACK 242 SHADE WITH FROSTED LENS
Light Source: 2700K CCT, 90 CRI LEDS
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 2790.8 lumens
Efficiency: N/A
Efficacy: 136.1 lumens/watt
Spacing Criteria (0/90/45): 1.21 / 1.21 / 1.33
Luminous Opening: Circular (Dia: 1.75' x H: 0')
CIE Type: Direct


Input Watts (W): 20.5
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT



TEST NUMBER: P979932

CATALOG NUMBER: PRLX-242-927-LL4-F-U-S-BLAK-X

Luminous Intensity Polar Plot



TEST NUMBER: P979932

CATALOG NUMBER: PRLX-242-927-LL4-F-U-S-BLAK-X

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102
1	110	106	102	98	107	103	100	97	99	96	94	95	93	91	92	90	88
2	100	93	86	81	98	91	85	80	87	83	78	84	80	77	81	78	75
3	92	82	74	68	89	80	73	67	77	71	66	75	69	65	72	68	64
4	84	73	64	58	82	71	63	57	69	62	57	67	61	56	64	59	55
5	77	65	56	50	75	64	56	50	62	55	49	60	53	48	58	52	48
6	72	59	50	44	70	58	49	43	56	48	43	54	48	43	53	47	42
7	66	53	44	38	65	52	44	38	51	43	38	49	43	38	48	42	37
8	62	48	40	34	60	48	40	34	46	39	34	45	39	34	44	38	34
9	58	44	36	31	56	44	36	31	43	36	31	42	35	31	41	35	30
10	54	41	33	28	53	41	33	28	40	33	28	39	32	28	38	32	28

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	4850
5°	4840
10°	4821
15°	4759
20°	4696
25°	4630
30°	4543
35°	4469
40°	4395
45°	4305
50°	4221
55°	4103
60°	3963
65°	3780
70°	3500
75°	1373
80°	0
85°	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 4305 cd/sqm

TEST NUMBER: P979932

CATALOG NUMBER: PRLX-242-927-LL4-F-U-S-BLAK-X

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	102.3	3.7
10°-20°	289.7	10.4
20°-30°	431.7	15.5
30°-40°	511.6	18.3
40°-50°	524.9	18.8
50°-60°	469.7	16.8
60°-70°	352.4	12.6
70°-80°	108.5	3.9
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	823.7	29.5
0°-40°	1335.3	47.8
0°-60°	2329.9	83.5
0°-90°	2790.8	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2790.8	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1084	
5°	1077	102
15°	1027	290
25°	938	432
35°	818	512
45°	680	525
55°	526	470
65°	357	352
75°	79	109
85°	0	0
90°	0	

TEST NUMBER: P979932

CATALOG NUMBER: PRLX-242-927-LL4-F-U-S-BLAK-X

CANDELA DISTRIBUTION (FULL):

	0°
0°	1083.8
2.5°	1082.9
5°	1077.4
7.5°	1070.1
10°	1060.9
12.5°	1046.3
15°	1027.2
17.5°	1007.1
20°	986.1
22.5°	963.2
25°	937.7
27.5°	909.4
30°	879.2
32.5°	848.2
35°	818.1
37.5°	785.2
40°	752.3
42.5°	715.8
45°	680.2
47.5°	643.7
50°	606.3
52.5°	566.1
55°	525.9
57.5°	483.9
60°	442.8
62.5°	399.9
65°	357.0
67.5°	312.3
70°	267.5
72.5°	198.1
75°	79.4
77.5°	3.7
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0

TEST NUMBER: P979932

CATALOG NUMBER: PRLX-242-927-LL4-F-U-S-BLAK-X

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	17.24	18.83	17.61	19.15	19.46	17.24	18.83	17.61	19.15	19.46
	3H	18.99	20.42	19.37	20.75	21.11	18.99	20.42	19.37	20.75	21.11
	4H	19.19	20.53	19.59	20.88	21.25	19.19	20.53	19.59	20.88	21.25
	6H	19.13	20.36	19.54	20.73	21.12	19.13	20.36	19.54	20.73	21.12
	8H	19.09	20.27	19.52	20.66	21.06	19.09	20.27	19.52	20.66	21.06
	12H	19.07	20.19	19.50	20.57	21.00	19.07	20.19	19.50	20.57	21.00
4H	2H	17.88	19.22	18.27	19.56	19.94	17.88	19.22	18.27	19.56	19.94
	3H	19.79	20.90	20.20	21.30	21.70	19.79	20.90	20.20	21.30	21.70
	4H	19.97	20.97	20.41	21.38	21.82	19.97	20.97	20.41	21.38	21.82
	6H	19.92	20.78	20.38	21.22	21.68	19.92	20.78	20.38	21.22	21.68
	8H	19.88	20.68	20.35	21.13	21.60	19.88	20.68	20.35	21.13	21.60
	12H	19.86	20.57	20.34	21.05	21.52	19.86	20.57	20.34	21.05	21.52
8H	4H	20.01	20.81	20.47	21.25	21.72	20.01	20.81	20.47	21.25	21.72
	6H	19.94	20.60	20.44	21.09	21.56	19.94	20.60	20.44	21.09	21.56
	8H	19.90	20.48	20.41	20.99	21.48	19.90	20.48	20.41	20.99	21.48
	12H	19.87	20.38	20.38	20.88	21.44	19.87	20.38	20.38	20.88	21.44
12H	4H	19.98	20.70	20.46	21.18	21.65	19.98	20.70	20.46	21.18	21.65
	6H	19.90	20.48	20.41	20.99	21.48	19.90	20.48	20.41	20.99	21.48
	8H	19.87	20.38	20.38	20.88	21.44	19.87	20.38	20.38	20.88	21.44

END OF REPORT