

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: PrentaLux

Report Number: P980450

Luminaire Tested: PRLX-243-935-74L-C-U-S-BLAK-X

Issue Date: 4/3/2025

Test Information

Test Method: LM-79-2019
Report Number: P980450
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-2502-353-36)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 4/3/2025
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PrentaLux
Catalog Number: PRLX-243-935-74L-C-U-S-BLAK-X
Description: 3D PRINTED LUMINAIRE, INTEGRAL LED LIGHT ENGINE, BLACK 243 SHADE WITH CLEAR LENS
Light Source: 3500K CCT, 90 CRI LEDS
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 5791.9 lumens
Efficiency: N/A
Efficacy: 94.2 lumens/watt
Spacing Criteria (0/90/45): 1.18 / 1.18 / 1.34
Luminous Opening: Circular (Dia: 1.67' x H: 0')
CIE Type: Direct

Input Watts (W): 61.5
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P980450

CATALOG NUMBER: PRLX-243-935-74L-C-U-S-BLAK-X

Luminous Intensity Polar Plot



TEST NUMBER: P980450

CATALOG NUMBER: PRLX-243-935-74L-C-U-S-BLAK-X

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	112	109	106	104	110	107	104	102	103	101	99		99	97	96		96
2	105	99	95	91	103	98	93	89	94	91	88		91	88	86		88
3	98	91	85	80	96	89	84	79	86	82	78		84	80	77		82
4	92	83	76	71	90	81	75	70	79	74	69		77	72	69		75
5	86	75	68	63	84	74	68	63	73	67	62		71	66	62		69
6	80	69	62	57	78	68	61	56	67	61	56		65	60	56		64
7	75	63	56	51	73	63	56	51	61	55	51		60	54	50		59
8	70	58	51	46	69	58	51	46	57	50	46		55	50	46		54
9	66	54	47	42	64	53	47	42	52	46	42		51	46	42		50
10	62	50	43	38	61	50	43	38	49	43	38		48	42	38		47

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	16613
5°	16232
10°	15722
15°	15366
20°	15200
25°	15130
30°	15040
35°	15033
40°	15011
45°	15009
50°	8700
55°	772
60°	116
65°	138
70°	170
75°	179
80°	134
85°	136

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 15009 cd/sqm

TEST NUMBER: P980450

CATALOG NUMBER: PRLX-243-935-74L-C-U-S-BLAK-X

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	308.3	5.3
10°-20°	850.6	14.7
20°-30°	1281.2	22.1
30°-40°	1561.8	27.0
40°-50°	1569.6	27.1
50°-60°	195.9	3.4
60°-70°	11.7	0.2
70°-80°	9.6	0.2
80°-90°	3.2	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2440.1	42.1
0°-40°	4001.9	69.1
0°-60°	5767.4	99.6
0°-90°	5791.9	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	5791.9	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	3367	
5°	3278	308
15°	3008	851
25°	2779	1281
35°	2496	1562
45°	2151	1570
55°	90	196
65°	12	12
75°	9	10
85°	2	3
90°	0	

TEST NUMBER: P980450

CATALOG NUMBER: PRLX-243-935-74L-C-U-S-BLAK-X

CANDELA DISTRIBUTION (FULL):

0°	
0°	3367.2
2.5°	3353.0
5°	3277.5
7.5°	3199.5
10°	3138.1
12.5°	3079.1
15°	3008.3
17.5°	2949.2
20°	2894.9
22.5°	2845.3
25°	2779.2
27.5°	2710.7
30°	2639.9
32.5°	2569.1
35°	2495.9
37.5°	2418.0
40°	2330.6
42.5°	2240.9
45°	2151.1
47.5°	2030.7
50°	1133.4
52.5°	214.9
55°	89.7
57.5°	28.3
60°	11.8
62.5°	11.8
65°	11.8
67.5°	11.8
70°	11.8
72.5°	11.8
75°	9.4
77.5°	7.1
80°	4.7
82.5°	4.7
85°	2.4
87.5°	2.4
90°	0.0

TEST NUMBER: P980450

CATALOG NUMBER: PRLX-243-935-74L-C-U-S-BLAK-X

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	3H	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	4H	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	6H	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	8H	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	12H	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
4H	2H	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	3H	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	4H	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	6H	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	8H	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	12H	0.00	0.00	0.00	0.00	0.07	0.00	0.00	0.00	0.00	0.07
8H	4H	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	6H	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	8H	0.00	0.00	0.00	0.00	0.32	0.00	0.00	0.00	0.00	0.32
	12H	0.00	0.00	0.00	0.00	0.58	0.00	0.00	0.00	0.00	0.58
12H	4H	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	6H	0.00	0.00	0.00	0.00	0.02	0.00	0.00	0.00	0.00	0.02
	8H	0.00	0.00	0.00	0.00	0.43	0.00	0.00	0.00	0.00	0.43

END OF REPORT