

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: PrentaLux

Report Number: P1245422

Luminaire Tested: PRLX-UNA-M-935-06L-U-NL

Issue Date: 1/30/2026

Test Information

Test Method: LM-79-2019
Report Number: P1245422
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-2412-299-24)
Test Lab: INNOVATION CENTER
Issue Date: 1/30/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PrentaLux
Catalog Number: PRLX-UNA-M-935-06L-U-NL
Description: 3D PRINTED PENDANT LED LUMINAIRE, MEDIUM LIGHT ENGINE, NATURAL LINES SHADE TEXT LIGHT LEVEL 4
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 496.0 lumens
Efficiency: N/A
Efficacy: 23.3 lumens/watt
Spacing Criteria (0/90/45): 0.21 / 0.21 / 0.18
Luminous Opening: Rectangular w/ Sides (W: 0.46' x L: 0.46' x H: 1.92')
CIE Type: General Diffuse

Input Watts (W): 21.3
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 28.75 FT

TEST NUMBER: P1245422

CATALOG NUMBER: PRLX-UNA-M-935-06L-U-NL

Luminous Intensity Polar Plot





TEST NUMBER: P1245422

CATALOG NUMBER: PRLX-UNA-M-935-06L-U-NL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10			
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0		
RCR																				
0	108	108	108	108	101	101	101	101	86	86	86	73	73	73	61	61	61	55		
1	95	90	84	79	88	83	78	74	70	67	64	59	56	54	48	46	45	39		
2	86	77	70	63	79	71	65	59	61	56	51	51	47	43	42	39	36	31		
3	78	68	59	53	72	63	55	49	53	48	43	45	40	36	37	33	30	26		
4	72	60	51	45	66	56	48	42	48	42	37	40	35	32	33	30	27	23		
5	67	54	45	39	61	50	43	37	43	37	32	37	32	28	31	27	24	21		
6	62	49	41	34	57	46	38	33	40	33	29	34	29	25	28	25	22	19		
7	58	45	37	31	53	42	35	29	37	31	26	31	27	23	27	23	20	17		
8	54	41	34	28	50	39	32	27	34	28	24	29	25	21	25	21	19	16		
9	51	38	31	26	47	36	29	25	32	26	22	28	23	20	24	20	17	15		
10	48	36	29	24	45	34	27	23	30	24	21	26	22	19	23	19	17	15		

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	47414
5°	23999
10°	4609
15°	1546
20°	923
25°	705
30°	581
35°	524
40°	478
45°	460
50°	446
55°	438
60°	441
65°	440
70°	450
75°	463
80°	472
85°	483

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 90°

Luminance: 500 cd/sqm

TEST NUMBER: P1245422

CATALOG NUMBER: PRLX-UNA-M-935-06L-U-NL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	41.1	8.3
10°-20°	19.7	4.0
20°-30°	17.1	3.4
30°-40°	20.5	4.1
40°-50°	25.3	5.1
50°-60°	30.8	6.2
60°-70°	36.0	7.3
70°-80°	40.8	8.2
80°-90°	43.8	8.8
90°-100°	44.9	9.1
100°-110°	43.7	8.8
110°-120°	39.8	8.0
120°-130°	33.4	6.7
130°-140°	25.8	5.2
140°-150°	17.8	3.6
150°-160°	10.4	2.1
160°-170°	4.4	0.9
170°-180°	0.7	0.1
0°-30°	77.9	15.7
0°-40°	98.4	19.8
0°-60°	154.5	31.2
0°-90°	275.1	55.5
90°-120°	128.4	25.9
90°-150°	205.5	41.4
90°-180°	221.0	44.6
0°-180°	496.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	925	
5°	637	41
15°	62	20
25°	37	17
35°	33	21
45°	33	25
55°	34	31
65°	36	36
75°	39	41
85°	40	33
90°	41	22
95°	41	34
105°	41	44
115°	40	40
125°	38	33
135°	34	26
145°	28	18
155°	22	10
165°	15	4
175°	5	1
180°	1	

TEST NUMBER: P1245422

CATALOG NUMBER: PRLX-UNA-M-935-06L-U-NL

CANDELA DISTRIBUTION (FULL):

0°	
0°	925.2
2.5°	996.9
5°	637.2
7.5°	222.3
10°	153.9
12.5°	88.1
15°	61.8
17.5°	50.0
20°	42.7
22.5°	38.8
25°	36.8
27.5°	34.9
30°	33.5
32.5°	32.9
35°	32.9
37.5°	32.2
40°	32.2
42.5°	32.2
45°	32.9
47.5°	32.9
50°	33.5
52.5°	33.5
55°	34.2
57.5°	34.9
60°	35.5
62.5°	35.5
65°	36.2
67.5°	36.8
70°	37.5
72.5°	38.1
75°	38.8
77.5°	38.8
80°	39.5
82.5°	40.1
85°	40.1
87.5°	40.1
90°	40.8
92.5°	40.8
95°	41.4
97.5°	41.4
100°	41.4
102.5°	41.4
105°	41.4
107.5°	41.4
110°	40.8

TEST NUMBER: P1245422

CATALOG NUMBER: PRLX-UNA-M-935-06L-U-NL

CANDELA DISTRIBUTION (continued):

	0°
112.5°	40.8
115°	40.1
117.5°	39.5
120°	38.8
122.5°	38.1
125°	37.5
127.5°	36.2
130°	35.5
132.5°	34.2
135°	33.5
137.5°	32.2
140°	30.9
142.5°	29.6
145°	28.3
147.5°	27.0
150°	25.6
152.5°	23.7
155°	22.4
157.5°	20.4
160°	19.1
162.5°	17.1
165°	15.1
167.5°	13.2
170°	11.2
172.5°	7.9
175°	4.6
177.5°	2.0
180°	0.7

TEST NUMBER: P1245422

CATALOG NUMBER: PRLX-UNA-M-935-06L-U-NL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room Dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	4.3	5.3	5.2	6.2	7.4	4.3	5.3	5.2	6.2	7.4
	3H	7.3	8.2	8.2	9.1	10.4	7.3	8.2	8.2	9.1	10.4
	4H	8.8	9.7	9.7	10.6	11.8	8.8	9.7	9.7	10.6	11.8
	6H	10.3	11.1	11.2	12.0	13.3	10.3	11.1	11.2	12.0	13.3
	8H	11.0	11.8	11.9	12.7	13.9	11.0	11.8	11.9	12.7	13.9
	12H	11.7	12.4	12.6	13.4	14.6	11.7	12.4	12.6	13.4	14.6
4H	2H	5.1	5.9	6.0	6.9	8.1	5.1	5.9	6.0	6.9	8.1
	3H	8.3	9.0	9.2	10.0	11.2	8.3	9.0	9.2	10.0	11.2
	4H	9.9	10.6	10.8	11.6	12.8	9.9	10.6	10.8	11.6	12.8
	6H	11.5	12.2	12.5	13.1	14.4	11.5	12.2	12.5	13.1	14.4
	8H	12.3	12.9	13.3	13.9	15.2	12.3	12.9	13.3	13.9	15.2
	12H	13.1	13.7	14.1	14.7	16.0	13.1	13.7	14.1	14.7	16.0
8H	4H	10.4	11.0	11.4	12.0	13.3	10.4	11.0	11.4	12.0	13.3
	6H	12.3	12.8	13.2	13.8	15.1	12.3	12.8	13.2	13.8	15.1
	8H	13.2	13.7	14.2	14.7	16.0	13.2	13.7	14.2	14.7	16.0
	12H	14.2	14.6	15.2	15.6	16.9	14.2	14.6	15.2	15.6	16.9
12H	4H	10.5	11.1	11.5	12.1	13.3	10.5	11.1	11.5	12.1	13.3
	6H	12.5	12.9	13.4	13.9	15.2	12.5	12.9	13.4	13.9	15.2
	8H	13.5	13.9	14.5	14.9	16.2	13.5	13.9	14.5	14.9	16.2

(END OF REPORT)