

Scaled data based on original data using
LM-79-2024 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: PrentaLux

Report Number: P1503732

Luminaire Tested: PRLX-SM4-03-LS-FS-010-XXXX-BRSS-XX-OC (3000K-650LM)

Issue Date: 7/28/2026

Test Information

Test Method: LM-79-2024
Report Number: P1503732
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-2606-836-15)
Test Lab: INNOVATION CENTER
Issue Date: 7/28/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PrentaLux
Catalog Number: PRLX-SM4-03-LS-FS-010-XXXX-BRSS-XX-OC (3000K-650LM)
Description: PrentaLux Fluxyn SM4 SURFACE MOUNT, DISC, OPEN CYLINDER, BRASS REFLECTOR
LIGHT LEVEL 1 - 650 NOMINAL LUMENS
Light Source: SELECTABLE CCT - 3000K CCT, 90 CRI
Ballast/Driver: ELECTRONIC DRIVER

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 425.0 lumens
Efficiency: N/A
Efficacy: 65.4 lumens/watt
Spacing Criteria (0/90/45): 1.06 / 1.06 / 1.14
Luminous Opening: Circular (Dia: 0.67' x H: 0')
CIE Type: Direct

Input Watts (W): 6.5
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1503732

CATALOG NUMBER: PRLX-SM4-03-LS-FS-010-XXXX-BRSS-XX-OC (3000K-650LM)

Luminous Intensity Polar Plot



TEST NUMBER: P1503732

CATALOG NUMBER: PRLX-SM4-03-LS-FS-010-XXXX-BRSS-XX-OC (3000K-650LM)

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10				0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0			
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			
1	111	107	103	100	108	104	101	98	100	97	95	96	94	92	93	91	89	87			
2	102	95	89	84	100	93	88	83	90	85	82	87	83	80	84	81	78	76			
3	94	85	78	73	92	84	77	72	81	75	71	78	74	70	76	72	68	66			
4	88	77	69	63	85	76	69	63	73	67	62	71	66	61	69	64	61	59			
5	81	70	62	56	79	69	61	56	67	60	55	65	59	55	63	58	54	52			
6	76	64	56	50	74	63	55	50	61	54	49	60	54	49	58	53	49	47			
7	71	59	51	45	69	58	50	45	56	50	45	55	49	44	54	48	44	42			
8	66	54	46	41	65	53	46	41	52	45	41	51	45	40	50	44	40	38			
9	62	50	42	37	61	49	42	37	48	42	37	47	41	37	46	41	37	35			
10	59	46	39	34	57	46	39	34	45	39	34	44	38	34	43	38	34	32			

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	7213
5°	7212
10°	7174
15°	6912
20°	6566
25°	6182
30°	5747
35°	5278
40°	4746
45°	4173
50°	3526
55°	2860
60°	2263
65°	2043
70°	1920
75°	1847
80°	1723
85°	1380

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 4173 cd/sqm

TEST NUMBER: P1503732

CATALOG NUMBER: PRLX-SM4-03-LS-FS-010-XXXX-BRSS-XX-OC (3000K-650LM)

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	22.1	5.2
10°-20°	60.8	14.3
20°-30°	83.5	19.6
30°-40°	87.4	20.6
40°-50°	73.8	17.4
50°-60°	48.3	11.4
60°-70°	28.0	6.6
70°-80°	16.4	3.8
80°-90°	4.7	1.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	166.4	39.1
0°-40°	253.8	59.7
0°-60°	375.9	88.5
0°-90°	425.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	425.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	234	
5°	233	22
15°	216	61
25°	182	83
35°	140	87
45°	96	74
55°	53	48
65°	28	28
75°	16	16
85°	4	5
90°	0	

TEST NUMBER: P1503732

CATALOG NUMBER: PRLX-SM4-03-LS-FS-010-XXXX-BRSS-XX-OC (3000K-650LM)

CANDELA DISTRIBUTION (FULL):

	0°
0°	233.9
2.5°	233.9
5°	233.0
7.5°	232.0
10°	229.1
12.5°	223.3
15°	216.5
17.5°	208.8
20°	200.1
22.5°	191.4
25°	181.7
27.5°	172.1
30°	161.4
32.5°	150.8
35°	140.2
37.5°	129.5
40°	117.9
42.5°	107.3
45°	95.7
47.5°	85.1
50°	73.5
52.5°	63.8
55°	53.2
57.5°	44.5
60°	36.7
62.5°	30.9
65°	28.0
67.5°	25.1
70°	21.3
72.5°	18.4
75°	15.5
77.5°	12.6
80°	9.7
82.5°	6.8
85°	3.9
87.5°	1.9
90°	0.0

(END OF REPORT)