

Scaled data based on original data using
LM-79-2024 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: PrentaLux

Report Number: P1503779

Luminaire Tested: PRLX-SM4-03-LS-FS-010-XXXX-WHTE-XX-OC (3500K-1000LM)

Issue Date: 7/28/2026

Test Information

Test Method: LM-79-2024
Report Number: P1503779
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-2606-836-13)
Test Lab: INNOVATION CENTER
Issue Date: 7/28/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PrentaLux
Catalog Number: PRLX-SM4-03-LS-FS-010-XXXX-WHTE-XX-OC (3500K-1000LM)
Description: PrentaLux Fluxyn SM4 SURFACE MOUNT, DISC, OPEN CYLINDER, WHITE REFLECTOR
LIGHT LEVEL 3 - 1000 NOMINAL LUMENS
Light Source: SELECTABLE CCT - 3500K CCT, 90 CRI
Ballast/Driver: ELECTRONIC DRIVER

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 776.5 lumens
Efficiency: N/A
Efficacy: 71.9 lumens/watt
Spacing Criteria (0/90/45): 1.07 / 1.07 / 1.14
Luminous Opening: Circular (Dia: 0.67' x H: 0')
CIE Type: Direct

Input Watts (W): 10.8
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1503779

CATALOG NUMBER: PRLX-SM4-03-LS-FS-010-XXXX-WHTE-XX-OC (3500K-1000LM)

Luminous Intensity Polar Plot





TEST NUMBER: P1503779

CATALOG NUMBER: PRLX-SM4-03-LS-FS-010-XXXX-WHTE-XX-OC (3500K-1000LM)

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10				0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0			
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			
1	110	106	103	99	108	104	101	98	100	97	95	96	94	92	93	91	89	87			
2	102	95	89	84	99	93	88	83	90	85	81	86	83	79	83	80	78	76			
3	94	85	78	72	92	83	77	71	81	75	70	78	73	69	75	71	68	66			
4	87	77	69	63	85	75	68	62	73	67	62	71	65	61	69	64	60	58			
5	81	69	61	55	79	68	61	55	66	60	55	64	59	54	63	58	53	52			
6	75	63	55	49	74	62	55	49	61	54	49	59	53	48	58	52	48	46			
7	70	58	50	44	69	57	50	44	56	49	44	54	48	44	53	48	43	42			
8	66	53	46	40	64	53	45	40	51	45	40	50	44	40	49	44	39	38			
9	62	49	42	37	60	49	42	37	48	41	36	47	41	36	46	40	36	34			
10	58	46	39	34	57	45	38	34	44	38	33	44	38	33	43	37	33	32			

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	12877
5°	12827
10°	12725
15°	12310
20°	11709
25°	11051
30°	10312
35°	9516
40°	8630
45°	7675
50°	6601
55°	5505
60°	4440
65°	3969
70°	3751
75°	3431
80°	3125
85°	2830

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 7675 cd/sqm

TEST NUMBER: P1503779

CATALOG NUMBER: PRLX-SM4-03-LS-FS-010-XXXX-WHTE-XX-OC (3500K-1000LM)

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	39.4	5.1
10°-20°	108.1	13.9
20°-30°	149.3	19.2
30°-40°	157.8	20.3
40°-50°	135.5	17.4
50°-60°	92.2	11.9
60°-70°	54.4	7.0
70°-80°	31.0	4.0
80°-90°	8.9	1.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	296.7	38.2
0°-40°	454.4	58.5
0°-60°	682.1	87.8
0°-90°	776.5	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	776.5	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	418	
5°	414	39
15°	386	108
25°	325	149
35°	253	158
45°	176	135
55°	102	92
65°	54	54
75°	29	31
85°	8	9
90°	0	

TEST NUMBER: P1503779

CATALOG NUMBER: PRLX-SM4-03-LS-FS-010-XXXX-WHTE-XX-OC (3500K-1000LM)

CANDELA DISTRIBUTION (FULL):

	0°
0°	417.6
2.5°	416.0
5°	414.4
7.5°	412.8
10°	406.4
12.5°	396.8
15°	385.6
17.5°	371.2
20°	356.8
22.5°	340.8
25°	324.8
27.5°	308.8
30°	289.6
32.5°	272.0
35°	252.8
37.5°	233.6
40°	214.4
42.5°	195.2
45°	176.0
47.5°	156.8
50°	137.6
52.5°	120.0
55°	102.4
57.5°	86.4
60°	72.0
62.5°	60.8
65°	54.4
67.5°	48.0
70°	41.6
72.5°	35.2
75°	28.8
77.5°	24.0
80°	17.6
82.5°	12.8
85°	8.0
87.5°	3.2
90°	0.0

(END OF REPORT)