

Scaled data based on original data using
LM-79-2024 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: PrentaLux

Report Number: P1503886

Luminaire Tested: PRLX-SM4-03-LS-FS-D2W-XXXX-BRSS-XX-OT (3500K-800LM)

Issue Date: 7/28/2026

Test Information

Test Method: LM-79-2024
Report Number: P1503886
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-2606-836-12)
Test Lab: INNOVATION CENTER
Issue Date: 7/28/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PrentaLux
Catalog Number: PRLX-SM4-03-LS-FS-D2W-XXXX-BRSS-XX-OT (3500K-800LM)
Description: PrentaLux Fluxyn SM4 SURFACE MOUNT, DISC, OPEN TAPERED, BRASS REFLECTOR
LIGHT LEVEL 2 - 800 NOMINAL LUMENS
Light Source: SELECTABLE CCT - 3500K CCT, 90 CRI - DIM TO WARM (1800K)
Ballast/Driver: ELECTRONIC DRIVER

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 452.8 lumens
Efficiency: N/A
Efficacy: 51.5 lumens/watt
Spacing Criteria (0/90/45): 1.09 / 1.09 / 1.14
Luminous Opening: Circular (Dia: 0.67' x H: 0')
CIE Type: Direct

Input Watts (W): 8.8
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1503886

CATALOG NUMBER: PRLX-SM4-03-LS-FS-D2W-XXXX-BRSS-XX-OT (3500K-800LM)

Luminous Intensity Polar Plot





TEST NUMBER: P1503886

CATALOG NUMBER: PRLX-SM4-03-LS-FS-D2W-XXXX-BRSS-XX-OT (3500K-800LM)

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10			
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0		
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100		
1	110	105	101	98	107	103	100	96	99	96	93	95	93	90	91	90	88	86		
2	101	93	87	82	98	92	86	81	88	83	79	85	81	77	82	79	76	74		
3	93	83	76	70	91	82	75	69	79	73	68	76	71	67	74	69	66	64		
4	86	75	67	61	84	74	66	60	71	65	59	69	63	59	67	62	58	56		
5	80	68	60	53	78	67	59	53	65	58	53	63	57	52	61	56	52	50		
6	74	62	54	48	72	61	53	47	59	52	47	58	51	47	56	51	46	44		
7	69	57	48	43	68	56	48	43	54	47	42	53	47	42	52	46	42	40		
8	65	52	44	39	63	51	44	39	50	43	38	49	43	38	48	42	38	36		
9	61	48	41	35	59	48	40	35	47	40	35	46	39	35	45	39	35	33		
10	57	45	37	32	56	44	37	32	43	37	32	42	36	32	42	36	32	30		

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	7111
5°	7110
10°	7077
15°	6988
20°	6701
25°	6294
30°	5815
35°	5285
40°	4714
45°	4091
50°	3497
55°	3000
60°	2868
65°	2933
70°	2975
75°	2955
80°	2788
85°	2371

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 4091 cd/sqm

TEST NUMBER: P1503886

CATALOG NUMBER: PRLX-SM4-03-LS-FS-D2W-XXXX-BRSS-XX-OT (3500K-800LM)

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	21.8	4.8
10°-20°	61.3	13.5
20°-30°	84.9	18.7
30°-40°	87.6	19.3
40°-50°	72.6	16.0
50°-60°	51.3	11.3
60°-70°	39.6	8.8
70°-80°	26.0	5.7
80°-90°	7.7	1.7
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	168.0	37.1
0°-40°	255.6	56.4
0°-60°	379.4	83.8
0°-90°	452.8	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	452.8	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	231	
5°	230	22
15°	219	61
25°	185	85
35°	140	88
45°	94	73
55°	56	51
65°	40	40
75°	25	26
85°	7	8
90°	0	

TEST NUMBER: P1503886

CATALOG NUMBER: PRLX-SM4-03-LS-FS-D2W-XXXX-BRSS-XX-OT (3500K-800LM)

CANDELA DISTRIBUTION (FULL):

	0°
0°	230.6
2.5°	230.4
5°	229.7
7.5°	228.2
10°	226.0
12.5°	223.2
15°	218.9
17.5°	212.2
20°	204.2
22.5°	195.0
25°	185.0
27.5°	174.6
30°	163.3
32.5°	151.9
35°	140.4
37.5°	128.7
40°	117.1
42.5°	105.4
45°	93.8
47.5°	83.1
50°	72.9
52.5°	63.9
55°	55.8
57.5°	50.2
60°	46.5
62.5°	43.3
65°	40.2
67.5°	36.8
70°	33.0
72.5°	29.1
75°	24.8
77.5°	20.4
80°	15.7
82.5°	11.2
85°	6.7
87.5°	2.6
90°	0.0

(END OF REPORT)