

Scaled data based on original data using
LM-79-2024 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: PrentaLux

Report Number: P1503917

Luminaire Tested: PRLX-SM4-03-LS-FS-D2W-XXXX-WHTE-XX-OC (4000K-1000LM)

Issue Date: 7/28/2026

Test Information

Test Method: LM-79-2024
Report Number: P1503917
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-2606-836-13)
Test Lab: INNOVATION CENTER
Issue Date: 7/28/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PrentaLux
Catalog Number: PRLX-SM4-03-LS-FS-D2W-XXXX-WHTE-XX-OC (4000K-1000LM)
Description: PrentaLux Fluxyn SM4 SURFACE MOUNT, DISC, OPEN CYLINDER, WHITE REFLECTOR
LIGHT LEVEL 3 - 1000 NOMINAL LUMENS
Light Source: SELECTABLE CCT - 4000K CCT, 90 CRI - DIM TO WARM (1800K)
Ballast/Driver: ELECTRONIC DRIVER

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 861.1 lumens
Efficiency: N/A
Efficacy: 74.9 lumens/watt
Spacing Criteria (0/90/45): 1.07 / 1.07 / 1.14
Luminous Opening: Circular (Dia: 0.67' x H: 0')
CIE Type: Direct

Input Watts (W): 11.5
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1503917

CATALOG NUMBER: PRLX-SM4-03-LS-FS-D2W-XXXX-WHTE-XX-OC (4000K-1000LM)

Luminous Intensity Polar Plot





TEST NUMBER: P1503917

CATALOG NUMBER: PRLX-SM4-03-LS-FS-D2W-XXXX-WHTE-XX-OC (4000K-1000LM)

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10				0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0			
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			
1	110	106	103	99	108	104	101	98	100	97	95	96	94	92	93	91	89	87			
2	102	95	89	84	99	93	88	83	90	85	81	86	83	79	83	80	78	76			
3	94	85	78	72	92	83	77	71	81	75	70	78	73	69	75	71	68	66			
4	87	77	69	63	85	75	68	62	73	67	62	71	65	61	69	64	60	58			
5	81	69	61	55	79	68	61	55	66	60	55	64	59	54	63	58	53	52			
6	75	63	55	49	74	62	55	49	61	54	49	59	53	48	58	52	48	46			
7	70	58	50	44	69	57	50	44	56	49	44	54	48	44	53	48	43	42			
8	66	53	46	40	64	53	45	40	51	45	40	50	44	40	49	44	39	38			
9	62	49	42	37	60	49	42	37	48	41	36	47	41	36	46	40	36	34			
10	58	46	39	34	57	45	38	34	44	38	33	44	38	33	43	37	33	32			

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	14280
5°	14227
10°	14112
15°	13651
20°	12985
25°	12255
30°	11437
35°	10555
40°	9572
45°	8513
50°	7321
55°	6107
60°	4928
65°	4400
70°	4156
75°	3801
80°	3463
85°	3149

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 8513 cd/sqm

TEST NUMBER: P1503917

CATALOG NUMBER: PRLX-SM4-03-LS-FS-D2W-XXXX-WHTE-XX-OC (4000K-1000LM)

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	43.7	5.1
10°-20°	119.9	13.9
20°-30°	165.5	19.2
30°-40°	175.0	20.3
40°-50°	150.3	17.5
50°-60°	102.3	11.9
60°-70°	60.3	7.0
70°-80°	34.4	4.0
80°-90°	9.9	1.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	329.1	38.2
0°-40°	504.0	58.5
0°-60°	756.6	87.9
0°-90°	861.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	861.1	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	463	
5°	460	44
15°	428	120
25°	360	166
35°	280	175
45°	195	150
55°	114	102
65°	60	60
75°	32	34
85°	9	10
90°	0	

TEST NUMBER: P1503917

CATALOG NUMBER: PRLX-SM4-03-LS-FS-D2W-XXXX-WHTE-XX-OC (4000K-1000LM)

CANDELA DISTRIBUTION (FULL):

0°	
0°	463.1
2.5°	461.4
5°	459.6
7.5°	457.8
10°	450.7
12.5°	440.1
15°	427.6
17.5°	411.7
20°	395.7
22.5°	378.0
25°	360.2
27.5°	342.5
30°	321.2
32.5°	301.7
35°	280.4
37.5°	259.1
40°	237.8
42.5°	216.5
45°	195.2
47.5°	173.9
50°	152.6
52.5°	133.1
55°	113.6
57.5°	95.8
60°	79.9
62.5°	67.4
65°	60.3
67.5°	53.2
70°	46.1
72.5°	39.0
75°	31.9
77.5°	26.6
80°	19.5
82.5°	14.2
85°	8.9
87.5°	3.5
90°	0.0

(END OF REPORT)