

Scaled data based on original data using
LM-79-2024 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: PrentaLux

Report Number: P1504092

Luminaire Tested: PRLX-SM6-03-LS-FS-D2W-XXXX-BRNZ-XX-OC (3000K-750LM)

Issue Date: 7/28/2026

Test Information

Test Method: LM-79-2024
Report Number: P1504092
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-2606-836-23)
Test Lab: INNOVATION CENTER
Issue Date: 7/28/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PrentaLux
Catalog Number: PRLX-SM6-03-LS-FS-D2W-XXXX-BRNZ-XX-OC (3000K-750LM)
Description: PrentaLux Fluxyn SM6 SURFACE MOUNT, DISC, OPEN CYLINDER, BRONZE REFLECTOR
LIGHT LEVEL 1 - 750 NOMINAL LUMENS
Light Source: SELECTABLE CCT - 3000K CCT, 90 CRI - DIM TO WARM (1800K)
Ballast/Driver: ELECTRONIC DRIVER

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 743.8 lumens
Efficiency: N/A
Efficacy: 93.0 lumens/watt
Spacing Criteria (0/90/45): 1.1 / 1.1 / 1.18
Luminous Opening: Circular (Dia: 1.17' x H: 0')
CIE Type: Direct

Input Watts (W): 8
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1504092

CATALOG NUMBER: PRLX-SM6-03-LS-FS-D2W-XXXX-BRNZ-XX-OC (3000K-750LM)

Luminous Intensity Polar Plot





TEST NUMBER: P1504092

CATALOG NUMBER: PRLX-SM6-03-LS-FS-D2W-XXXX-BRNZ-XX-OC (3000K-750LM)

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10			
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0		
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100		
1	110	106	103	99	108	104	101	98	100	97	95	96	94	92	92	91	89	87		
2	102	95	89	84	99	93	87	83	89	85	81	86	82	79	83	80	77	75		
3	94	85	77	72	92	83	76	71	80	75	70	78	73	69	75	71	68	66		
4	87	76	68	62	85	75	68	62	73	66	61	70	65	60	68	64	60	58		
5	81	69	61	55	79	68	60	55	66	59	54	64	58	54	62	57	53	51		
6	75	63	55	49	73	62	54	49	60	53	48	59	53	48	57	52	47	46		
7	70	58	49	44	68	57	49	44	55	48	43	54	48	43	53	47	43	41		
8	65	53	45	40	64	52	45	40	51	44	39	50	44	39	49	43	39	37		
9	61	49	41	36	60	48	41	36	47	41	36	46	40	36	45	40	36	34		
10	58	45	38	33	57	45	38	33	44	37	33	43	37	33	42	37	33	31		

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	3833
5°	3859
10°	3836
15°	3713
20°	3567
25°	3389
30°	3185
35°	2970
40°	2737
45°	2473
50°	2162
55°	1817
60°	1458
65°	1167
70°	1148
75°	1082
80°	1032
85°	901

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 2473 cd/sqm

TEST NUMBER: P1504092

CATALOG NUMBER: PRLX-SM6-03-LS-FS-D2W-XXXX-BRNZ-XX-OC (3000K-750LM)

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	36.3	4.9
10°-20°	100.2	13.5
20°-30°	140.2	18.8
30°-40°	150.9	20.3
40°-50°	133.7	18.0
50°-60°	93.2	12.5
60°-70°	51.2	6.9
70°-80°	29.5	4.0
80°-90°	8.8	1.2
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	276.7	37.2
0°-40°	427.5	57.5
0°-60°	654.4	88.0
0°-90°	743.8	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	743.8	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	381	
5°	382	36
15°	356	100
25°	305	140
35°	242	151
45°	174	134
55°	104	93
65°	49	51
75°	28	30
85°	8	9
90°	0	

TEST NUMBER: P1504092

CATALOG NUMBER: PRLX-SM6-03-LS-FS-D2W-XXXX-BRNZ-XX-OC (3000K-750LM)

CANDELA DISTRIBUTION (FULL):

0°	
0°	380.7
2.5°	380.7
5°	381.8
7.5°	380.7
10°	375.2
12.5°	367.4
15°	356.2
17.5°	345.1
20°	332.9
22.5°	319.5
25°	305.0
27.5°	290.6
30°	273.9
32.5°	258.3
35°	241.6
37.5°	224.9
40°	208.2
42.5°	191.5
45°	173.7
47.5°	155.9
50°	138.0
52.5°	121.3
55°	103.5
57.5°	87.9
60°	72.4
62.5°	59.0
65°	49.0
67.5°	43.4
70°	39.0
72.5°	33.4
75°	27.8
77.5°	22.3
80°	17.8
82.5°	12.2
85°	7.8
87.5°	3.3
90°	0.0

(END OF REPORT)