

Scaled data based on original data using
LM-79-2024 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: PrentaLux

Report Number: P1504138

Luminaire Tested: PRLX-SM6-03-LS-FS-D2W-XXXX-BRSS-XX-OC (3000K-900LM)

Issue Date: 7/28/2026

Test Information

Test Method: LM-79-2024
Report Number: P1504138
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-2606-836-24)
Test Lab: INNOVATION CENTER
Issue Date: 7/28/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PrentaLux
Catalog Number: PRLX-SM6-03-LS-FS-D2W-XXXX-BRSS-XX-OC (3000K-900LM)
Description: PrentaLux Fluxyn SM6 SURFACE MOUNT, DISC, OPEN CYLINDER, BRASS REFLECTOR
LIGHT LEVEL 2 - 900 NOMINAL LUMENS
Light Source: SELECTABLE CCT - 3000K CCT, 90 CRI - DIM TO WARM (1800K)
Ballast/Driver: ELECTRONIC DRIVER

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 902.5 lumens
Efficiency: N/A
Efficacy: 94.0 lumens/watt
Spacing Criteria (0/90/45): 1.09 / 1.09 / 1.18
Luminous Opening: Circular (Dia: 1.17' x H: 0')
CIE Type: Direct

Input Watts (W): 9.6
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1504138

CATALOG NUMBER: PRLX-SM6-03-LS-FS-D2W-XXXX-BRSS-XX-OC (3000K-900LM)

Luminous Intensity Polar Plot





TEST NUMBER: P1504138

CATALOG NUMBER: PRLX-SM6-03-LS-FS-D2W-XXXX-BRSS-XX-OC (3000K-900LM)

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10				0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0			
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			
1	110	106	103	99	108	104	101	98	100	97	95	96	94	92	92	91	89	87			
2	102	95	89	84	99	93	87	83	89	85	81	86	82	79	83	80	77	75			
3	94	85	77	72	92	83	76	71	80	75	70	78	73	69	75	71	68	66			
4	87	76	68	62	85	75	68	62	72	66	61	70	65	60	68	63	60	58			
5	81	69	61	55	79	68	60	55	66	59	54	64	58	53	62	57	53	51			
6	75	63	55	49	73	62	54	49	60	53	48	59	52	48	57	52	47	45			
7	70	57	49	44	68	57	49	44	55	48	43	54	48	43	53	47	43	41			
8	65	53	45	40	64	52	45	39	51	44	39	50	44	39	49	43	39	37			
9	61	49	41	36	60	48	41	36	47	40	36	46	40	36	45	40	35	34			
10	58	45	38	33	56	45	38	33	44	37	33	43	37	33	42	37	33	31			

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	4654
5°	4672
10°	4644
15°	4498
20°	4310
25°	4114
30°	3855
35°	3602
40°	3327
45°	2996
50°	2629
55°	2221
60°	1770
65°	1427
70°	1410
75°	1346
80°	1235
85°	1074

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 2996 cd/sqm

TEST NUMBER: P1504138

CATALOG NUMBER: PRLX-SM6-03-LS-FS-D2W-XXXX-BRSS-XX-OC (3000K-900LM)

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	43.9	4.9
10°-20°	121.2	13.4
20°-30°	169.6	18.8
30°-40°	182.8	20.3
40°-50°	162.1	18.0
50°-60°	113.4	12.6
60°-70°	62.5	6.9
70°-80°	36.5	4.0
80°-90°	10.5	1.2
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	334.7	37.1
0°-40°	517.5	57.3
0°-60°	793.0	87.9
0°-90°	902.5	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	902.5	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	462	
5°	462	44
15°	432	121
25°	370	170
35°	293	183
45°	210	162
55°	126	113
65°	60	63
75°	35	37
85°	9	11
90°	0	

TEST NUMBER: P1504138

CATALOG NUMBER: PRLX-SM6-03-LS-FS-D2W-XXXX-BRSS-XX-OC (3000K-900LM)

CANDELA DISTRIBUTION (FULL):

0°	
0°	462.2
2.5°	462.2
5°	462.2
7.5°	460.8
10°	454.2
12.5°	444.9
15°	431.5
17.5°	416.9
20°	402.2
22.5°	386.2
25°	370.3
27.5°	350.3
30°	331.6
32.5°	311.7
35°	293.0
37.5°	273.0
40°	253.1
42.5°	231.7
45°	210.4
47.5°	189.1
50°	167.8
52.5°	147.8
55°	126.5
57.5°	106.6
60°	87.9
62.5°	71.9
65°	59.9
67.5°	53.3
70°	47.9
72.5°	41.3
75°	34.6
77.5°	28.0
80°	21.3
82.5°	14.7
85°	9.3
87.5°	4.0
90°	0.0

(END OF REPORT)