

Scaled data based on original data using
LM-79-2024 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: PrentaLux

Report Number: P1504203

Luminaire Tested: PRLX-SM6-03-LS-FS-D2W-XXXX-WHTE-XX-OT (4000K-750LM)

Issue Date: 7/28/2026

Test Information

Test Method: LM-79-2024
Report Number: P1504203
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-2606-836-19)
Test Lab: INNOVATION CENTER
Issue Date: 7/28/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PrentaLux
Catalog Number: PRLX-SM6-03-LS-FS-D2W-XXXX-WHITE-XX-OT (4000K-750LM)
Description: PrentaLux Fluxyn SM6 SURFACE MOUNT, DISC, OPEN TAPERED, WHITE REFLECTOR
LIGHT LEVEL 1 - 750 NOMINAL LUMENS
Light Source: SELECTABLE CCT - 4000K CCT, 90 CRI - DIM TO WARM (1800K)
Ballast/Driver: ELECTRONIC DRIVER

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 667.5 lumens
Efficiency: N/A
Efficacy: 83.4 lumens/watt
Spacing Criteria (0/90/45): 1.17 / 1.17 / 1.24
Luminous Opening: Circular (Dia: 1.17' x H: 0')
CIE Type: Direct

Input Watts (W): 8
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1504203

CATALOG NUMBER: PRLX-SM6-03-LS-FS-D2W-XXXX-WHTE-XX-OT (4000K-750LM)

Luminous Intensity Polar Plot



TEST NUMBER: P1504203

CATALOG NUMBER: PRLX-SM6-03-LS-FS-D2W-XXXX-WHTE-XX-OT (4000K-750LM)

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10			
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0		
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100		
1	109	105	101	97	107	102	99	95	98	95	92	94	92	90	91	89	87	85		
2	100	92	86	80	97	90	84	79	87	82	77	84	79	76	81	77	74	72		
3	92	82	74	68	89	80	73	67	77	71	66	75	69	65	72	68	64	62		
4	85	73	65	58	82	72	64	58	69	63	57	67	61	56	65	60	56	54		
5	78	66	57	51	76	65	57	51	63	56	50	61	54	50	59	53	49	47		
6	72	60	51	45	71	59	51	45	57	50	44	55	49	44	54	48	44	42		
7	67	54	46	40	66	54	46	40	52	45	40	51	44	39	49	44	39	37		
8	63	50	42	36	61	49	41	36	48	41	36	47	40	36	46	40	35	34		
9	59	46	38	33	58	45	38	33	44	37	33	43	37	32	42	36	32	30		
10	55	43	35	30	54	42	35	30	41	34	30	40	34	30	39	34	29	28		

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	2898
5°	2909
10°	2908
15°	2894
20°	2853
25°	2756
30°	2622
35°	2479
40°	2324
45°	2130
50°	1917
55°	1710
60°	1528
65°	1539
70°	1569
75°	1544
80°	1513
85°	1305

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 2130 cd/sqm

TEST NUMBER: P1504203

CATALOG NUMBER: PRLX-SM6-03-LS-FS-D2W-XXXX-WHTE-XX-OT (4000K-750LM)

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	27.3	4.1
10°-20°	78.3	11.7
20°-30°	114.0	17.1
30°-40°	126.0	18.9
40°-50°	115.3	17.3
50°-60°	87.6	13.1
60°-70°	64.0	9.6
70°-80°	41.9	6.3
80°-90°	13.1	2.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	219.6	32.9
0°-40°	345.6	51.8
0°-60°	548.6	82.2
0°-90°	667.5	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	667.5	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	288	
5°	288	27
15°	278	78
25°	248	114
35°	202	126
45°	150	115
55°	97	88
65°	65	64
75°	40	42
85°	11	13
90°	0	

TEST NUMBER: P1504203

CATALOG NUMBER: PRLX-SM6-03-LS-FS-D2W-XXXX-WHTE-XX-OT (4000K-750LM)

CANDELA DISTRIBUTION (FULL):

	0°
0°	287.8
2.5°	287.8
5°	287.8
7.5°	285.5
10°	284.4
12.5°	282.1
15°	277.6
17.5°	273.1
20°	266.3
22.5°	258.3
25°	248.1
27.5°	237.9
30°	225.5
32.5°	214.2
35°	201.7
37.5°	189.2
40°	176.8
42.5°	163.2
45°	149.6
47.5°	136.0
50°	122.4
52.5°	109.9
55°	97.4
57.5°	86.1
60°	75.9
62.5°	70.3
65°	64.6
67.5°	58.9
70°	53.3
72.5°	46.5
75°	39.7
77.5°	32.9
80°	26.1
82.5°	19.3
85°	11.3
87.5°	4.5
90°	0.0

(END OF REPORT)