

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: PrentaLux

Report Number: P1221166

Luminaire Tested: PRLX-UHBS2-1218-MV-L8C5-BLAK-08 (3000K_L12_Medium_120V)

Issue Date: 1/21/2026

Test Information

Test Method: LM-79-2019
Report Number: P1221166
TEST IS SCALED FROM IESNA LM-79-24 TEST DATA (G2-2510-574-12)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 1/21/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PrentaLux
Catalog Number: PRLX-UHBS2-1218-MV-L8C5-BLAK-08 (3000K_L12_Medium_120V)
Description: PrentaLux UHBS2 SELECTABLE HIGH BAY. 1218 LIGHT ENGINE, BLACK SHADE, MEDIUM DISTRIBUTION.
LIGHT LEVEL 1 - 12,000 LUMENS
Light Source: 3000K CCT, 80 CRI LEDS
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 8338.1 lumens
Efficiency: N/A
Efficacy: 102.4 lumens/watt
Spacing Criteria (0/90/45): 1.13 / 1.13 / 1.02
Luminous Opening: Vertical Cylinder (Dia: 1.58' x H: 0.67')
CIE Type: Direct

Input Watts (W): 81.4
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1221166

CATALOG NUMBER: PRLX-UHBS2-1218-MV-L8C5-BLAK-08 (3000K_L12_Medium_120V)

Luminous Intensity Polar Plot



TEST NUMBER: P1221166

CATALOG NUMBER: PRLX-UHBS2-1218-MV-L8C5-BLAK-08 (3000K_L12_Medium_120V)

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102
1	113	110	108	105	111	108	106	104	104	102	100	100	99	97	97	96	95
2	107	102	98	94	105	100	96	93	97	94	91	94	91	89	91	89	87
3	101	95	89	85	99	93	88	84	91	86	83	88	85	82	86	83	81
4	96	88	82	78	94	87	81	77	84	80	76	82	78	75	81	77	74
5	91	82	76	71	89	81	75	71	79	74	70	77	73	69	76	72	69
6	86	76	70	65	84	75	69	65	74	69	65	72	68	64	71	67	64
7	81	71	65	60	80	70	64	60	69	64	60	68	63	59	67	62	59
8	77	67	60	56	75	66	60	56	65	59	55	64	59	55	63	58	55
9	73	62	56	52	71	62	56	52	61	55	52	60	55	51	59	55	51
10	69	59	53	48	68	58	52	48	57	52	48	57	52	48	56	51	48

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	38060
5°	36447
10°	34911
15°	33481
20°	31296
25°	28886
30°	25040
35°	17397
40°	9767
45°	3785
50°	1762
55°	341
60°	133
65°	122
70°	115
75°	103
80°	82
85°	50

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 3785 cd/sqm

TEST NUMBER: P1221166

CATALOG NUMBER: PRLX-UHBS2-1218-MV-L8C5-BLAK-08 (3000K_L12_Medium_120V)

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	661.4	7.9
10°-20°	1898.8	22.8
20°-30°	2729.6	32.7
30°-40°	2211.6	26.5
40°-50°	687.0	8.2
50°-60°	100.3	1.2
60°-70°	20.1	0.2
70°-80°	15.3	0.2
80°-90°	6.2	0.1
90°-100°	0.1	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.4	0.0
130°-140°	1.1	0.0
140°-150°	2.0	0.0
150°-160°	2.1	0.0
160°-170°	1.7	0.0
170°-180°	0.7	0.0
0°-30°	5289.8	63.4
0°-40°	7501.4	90.0
0°-60°	8288.6	99.4
0°-90°	8330.2	99.9
90°-120°	0.1	0.0
90°-150°	3.6	0.0
90°-180°	8.0	0.1
0°-180°	8338.1	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	6962	
5°	6953	661
15°	6766	1899
25°	5986	2730
35°	3585	2212
45°	752	687
55°	63	100
65°	20	20
75°	15	15
85°	6	6
90°	1	1
95°	0	0
105°	0	0
115°	0	0
125°	0	0
135°	2	1
145°	3	2
155°	5	2
165°	6	2
175°	7	1
180°	7	

TEST NUMBER: P1221166

CATALOG NUMBER: PRLX-UHBS2-1218-MV-L8C5-BLAK-08 (3000K_L12_Medium_120V)

CANDELA DISTRIBUTION (FULL):

0°	
0°	6961.9
2.5°	6948.2
5°	6953.0
7.5°	6929.6
10°	6883.5
12.5°	6842.3
15°	6765.5
17.5°	6621.5
20°	6429.1
22.5°	6222.1
25°	5986.0
27.5°	5703.8
30°	5194.4
32.5°	4444.0
35°	3585.3
37.5°	2720.9
40°	1984.3
42.5°	1323.7
45°	752.0
47.5°	405.1
50°	339.6
52.5°	181.1
55°	63.1
57.5°	33.2
60°	23.4
62.5°	21.0
65°	20.2
67.5°	19.4
70°	17.8
72.5°	16.2
75°	14.6
77.5°	12.9
80°	10.5
82.5°	8.1
85°	5.7
87.5°	3.2
90°	0.8
92.5°	0.0
95°	0.0
97.5°	0.0
100°	0.0
102.5°	0.0
105°	0.0
107.5°	0.0
110°	0.0

TEST NUMBER: P1221166

CATALOG NUMBER: PRLX-UHBS2-1218-MV-L8C5-BLAK-08 (3000K_L12_Medium_120V)

CANDELA DISTRIBUTION (continued):

	0°
112.5°	0.0
115°	0.0
117.5°	0.0
120°	0.0
122.5°	0.0
125°	0.0
127.5°	0.8
130°	0.8
132.5°	0.8
135°	1.6
137.5°	1.6
140°	2.4
142.5°	2.4
145°	3.2
147.5°	4.0
150°	4.0
152.5°	4.0
155°	4.9
157.5°	4.9
160°	5.7
162.5°	5.7
165°	5.7
167.5°	6.5
170°	6.5
172.5°	6.5
175°	7.3
177.5°	7.3
180°	7.3

TEST NUMBER: P1221166

CATALOG NUMBER: PRLX-UHBS2-1218-MV-L8C5-BLAK-08 (3000K_L12_Medium_120V)

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	3H	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	4H	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	6H	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	8H	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	12H	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
4H	2H	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	3H	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	4H	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	6H	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	8H	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	12H	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
8H	4H	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	6H	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	8H	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	12H	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
12H	4H	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	6H	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	8H	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

END OF REPORT