

Scaled data based on original data using
LM-79-2024 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: PrentaLux

Report Number: P1504685

Luminaire Tested: PRLX-UHBS2-1218-MV-L8C5-U-B-04-TRWH-PS (4000K_L16_Narrow_120V)

Issue Date: 7/31/2026

Test Information

Test Method: LM-79-2024
Report Number: P1504685
TEST IS SCALED FROM IESNA LM-79-24 TEST DATA (G2-2602-677-37)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 7/31/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PrentaLux
Catalog Number: PRLX-UHBS2-1218-MV-L8C5-U-B-04-TRWH-PS (4000K_L16_Narrow_120V)
Description: PrentaLux UHBS2 4-INCH SELECTABLE HIGH BAY 1218 LIGHT ENGINE, CONIC
TRANSLUCENT WHITE SHADE, NARROW DISTRIBUTION
LIGHT LEVEL 2 - 16,000 LUMENS
Light Source: 4000K CCT, 80 CRI LEDS
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 14595.9 lumens
Efficiency: N/A
Efficacy: 146.7 lumens/watt
Spacing Criteria (0/90/45): 0.96 / 0.96 / 0.99
Luminous Opening: Ellipsoidal Spheroid (W: 1.26' x L: 1.26' x H: 0.58')
CIE Type: Direct

Input Watts (W): 99.5
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1504685

CATALOG NUMBER: PRLX-UHBS2-1218-MV-L8C5-U-B-04-TRWH-PS (4000K_L16_Narrow_120V)

Luminous Intensity Polar Plot






TEST NUMBER: P1504685

CATALOG NUMBER: PRLX-UHBS2-1218-MV-L8C5-U-B-04-TRWH-PS (4000K_L16_Narrow_120V)

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10			
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0		
RCR																				
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	100	100	100	98		
1	111	108	105	102	108	105	102	100	101	99	96	97	95	93	93	92	90	88		
2	104	98	93	88	101	96	91	87	92	88	85	89	86	83	86	83	81	79		
3	97	89	83	78	95	87	81	77	84	79	75	81	77	74	79	75	72	71		
4	91	81	74	69	88	80	73	68	77	72	67	75	70	66	73	69	65	63		
5	85	74	67	62	83	73	66	61	71	65	61	69	64	60	67	63	59	57		
6	79	68	61	56	78	67	61	56	66	60	55	64	59	54	62	58	54	52		
7	74	63	56	51	73	62	55	51	61	55	50	59	54	50	58	53	49	48		
8	70	59	51	46	69	58	51	46	57	50	46	55	50	46	54	49	45	44		
9	66	55	48	43	65	54	47	43	53	47	42	52	46	42	51	46	42	40		
10	62	51	44	40	61	50	44	39	49	43	39	48	43	39	47	42	39	37		

AVERAGE LUMINANCE (cd/sqm):



MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: -
Vertical Angle: -
Luminance: -

TEST NUMBER: P1504685

CATALOG NUMBER: PRLX-UHBS2-1218-MV-L8C5-U-B-04-TRWH-PS (4000K_L16_Narrow_120V)

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	977.9	6.7
10°-20°	2603.9	17.8
20°-30°	3338.1	22.9
30°-40°	3000.1	20.6
40°-50°	2384.5	16.3
50°-60°	1270.4	8.7
60°-70°	404.4	2.8
70°-80°	229.2	1.6
80°-90°	119.5	0.8
90°-100°	47.6	0.3
100°-110°	47.5	0.3
110°-120°	44.9	0.3
120°-130°	39.6	0.3
130°-140°	32.9	0.2
140°-150°	26.0	0.2
150°-160°	17.7	0.1
160°-170°	9.2	0.1
170°-180°	2.6	0.0
0°-30°	6919.9	47.4
0°-40°	9920.1	68.0
0°-60°	13574.9	93.0
0°-90°	14327.9	98.2
90°-120°	139.9	1.0
90°-150°	238.4	1.6
90°-180°	268.0	1.8
0°-180°	14595.9	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	10516	
5°	10392	978
15°	9312	2604
25°	7317	3338
35°	4775	3000
45°	3022	2384
55°	1372	1270
65°	382	404
75°	219	229
85°	110	103
90°	44	28
95°	44	36
105°	45	48
115°	45	45
125°	44	40
135°	43	33
145°	42	26
155°	38	18
165°	32	9
175°	26	3
180°	26	

TEST NUMBER: P1504685

CATALOG NUMBER: PRLX-UHBS2-1218-MV-L8C5-U-B-04-TRWH-PS (4000K_L16_Narrow_120V)

CANDELA DISTRIBUTION (FULL):

0°	
0°	10515.8
2.5°	10464.9
5°	10391.7
7.5°	10222.8
10°	9950.2
12.5°	9651.2
15°	9311.5
17.5°	8901.6
20°	8425.6
22.5°	7898.8
25°	7317.0
27.5°	6685.4
30°	6029.3
32.5°	5380.4
35°	4775.3
37.5°	4233.2
40°	3755.1
42.5°	3323.9
45°	3021.8
47.5°	2907.9
50°	2488.8
52.5°	1968.1
55°	1372.1
57.5°	834.0
60°	644.8
62.5°	501.4
65°	382.4
67.5°	304.1
70°	258.3
72.5°	231.9
75°	218.7
77.5°	200.4
80°	174.9
82.5°	144.4
85°	109.8
87.5°	75.3
90°	43.7
92.5°	42.7
95°	43.7
97.5°	43.7
100°	44.8
102.5°	44.8
105°	44.8
107.5°	44.8
110°	45.8

TEST NUMBER: P1504685

CATALOG NUMBER: PRLX-UHBS2-1218-MV-L8C5-U-B-04-TRWH-PS (4000K_L16_Narrow_120V)

CANDELA DISTRIBUTION (continued):

	0°
112.5°	45.8
115°	44.8
117.5°	44.8
120°	44.8
122.5°	44.8
125°	43.7
127.5°	43.7
130°	43.7
132.5°	42.7
135°	42.7
137.5°	41.7
140°	41.7
142.5°	41.7
145°	41.7
147.5°	40.7
150°	40.7
152.5°	39.7
155°	37.6
157.5°	36.6
160°	35.6
162.5°	33.6
165°	32.5
167.5°	30.5
170°	29.5
172.5°	27.5
175°	26.4
177.5°	26.4
180°	26.4

(END OF REPORT)