

Scaled data based on original data using
LM-79-2024 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: PrentaLux

Report Number: P1504730

Luminaire Tested: PRLX-UHBS2-1218-MV-L8C5-U-B-04-WHGL-PS (4000K_L16_Narrow_120V)

Issue Date: 7/31/2026

Test Information

Test Method: LM-79-2024
Report Number: P1504730
TEST IS SCALED FROM IESNA LM-79-24 TEST DATA (G2-2602-677-34)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 7/31/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PrentaLux
Catalog Number: PRLX-UHBS2-1218-MV-L8C5-U-B-04-WHGL-PS (4000K_L16_Narrow_120V)
Description: PrentaLux UHBS2 4-INCH SELECTABLE HIGH BAY 1218 LIGHT ENGINE, CONIC WHITE SHADE, NARROW DISTRIBUTION
LIGHT LEVEL 2 - 16,000 LUMENS
Light Source: 4000K CCT, 80 CRI LEDS
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 14557.5 lumens
Efficiency: N/A
Efficacy: 146.3 lumens/watt
Spacing Criteria (0/90/45): 0.97 / 0.97 / 1
Luminous Opening: Circular (Dia: 1.26' x H: 0')
CIE Type: Direct

Input Watts (W): 99.5
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1504730

CATALOG NUMBER: PRLX-UHBS2-1218-MV-L8C5-U-B-04-WHGL-PS (4000K_L16_Narrow_120V)

Luminous Intensity Polar Plot



TEST NUMBER: P1504730

CATALOG NUMBER: PRLX-UHBS2-1218-MV-L8C5-U-B-04-WHGL-PS (4000K_L16_Narrow_120V)

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10			
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0		
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100		
1	112	108	105	102	109	106	103	100	102	99	97	98	96	94	95	93	92	90		
2	104	98	93	89	102	96	92	88	93	89	86	90	87	84	87	84	82	80		
3	97	89	83	78	95	88	82	77	85	80	76	82	78	75	80	76	73	72		
4	91	81	74	69	89	80	74	69	78	72	68	76	71	67	74	70	66	64		
5	85	75	67	62	83	74	67	62	72	66	61	70	65	60	68	64	60	58		
6	80	69	61	56	78	68	61	56	66	60	55	65	59	55	63	58	55	53		
7	75	63	56	51	73	63	56	51	61	55	50	60	54	50	59	54	50	48		
8	70	59	52	47	69	58	51	47	57	51	46	56	50	46	55	50	46	44		
9	66	55	48	43	65	54	47	43	53	47	43	52	46	42	51	46	42	41		
10	63	51	44	40	61	51	44	40	50	44	39	49	43	39	48	43	39	38		

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	90446
5°	89837
10°	87265
15°	83502
20°	78048
25°	70918
30°	61470
35°	51435
40°	43279
45°	37338
50°	34185
55°	21074
60°	11849
65°	8581
70°	7438
75°	8230
80°	9276
85°	9593

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 47.5°

Luminance: 37971 cd/sqm

TEST NUMBER: P1504730

CATALOG NUMBER: PRLX-UHBS2-1218-MV-L8C5-U-B-04-WHGL-PS (4000K_L16_Narrow_120V)

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	973.9	6.7
10°-20°	2607.6	17.9
20°-30°	3384.5	23.2
30°-40°	3061.2	21.0
40°-50°	2427.0	16.7
50°-60°	1302.0	8.9
60°-70°	440.9	3.0
70°-80°	256.8	1.8
80°-90°	103.6	0.7
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	6966.0	47.9
0°-40°	10027.2	68.9
0°-60°	13756.1	94.5
0°-90°	14557.5	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	14557.5	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	10450	
5°	10340	974
15°	9319	2608
25°	7426	3385
35°	4868	3061
45°	3050	2427
55°	1396	1302
65°	419	441
75°	246	257
85°	97	104
90°	0	

TEST NUMBER: P1504730

CATALOG NUMBER: PRLX-UHBS2-1218-MV-L8C5-U-B-04-WHGL-PS (4000K_L16_Narrow_120V)

CANDELA DISTRIBUTION (FULL):

	0°
0°	10449.6
2.5°	10400.8
5°	10339.8
7.5°	10183.2
10°	9928.9
12.5°	9647.2
15°	9318.6
17.5°	8924.0
20°	8473.4
22.5°	7978.1
25°	7425.8
27.5°	6805.4
30°	6150.4
32.5°	5499.4
35°	4867.8
37.5°	4316.6
40°	3830.4
42.5°	3398.1
45°	3050.3
47.5°	2963.8
50°	2538.7
52.5°	2006.7
55°	1396.5
57.5°	867.6
60°	684.5
62.5°	538.0
65°	419.0
67.5°	340.7
70°	293.9
72.5°	265.5
75°	246.1
77.5°	220.7
80°	186.1
82.5°	143.4
85°	96.6
87.5°	47.8
90°	0.0

(END OF REPORT)