

Scaled data based on original data using
LM-79-2024 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: PrentaLux

Report Number: P1504255

Luminaire Tested: PRLX-UHBS2-1218-MV-L8C5-U-A-04-BLAK-PS (6500K_L18_Medium_120V)

Issue Date: 7/31/2026

Test Information

Test Method: LM-79-2024
Report Number: P1504255
TEST IS SCALED FROM IESNA LM-79-24 TEST DATA (G2-2602-677-17)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 7/31/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PrentaLux
Catalog Number: PRLX-UHBS2-1218-MV-L8C5-U-A-04-BLAK-PS (6500K_L18_Medium_120V)
Description: PrentaLux UHBS2 4-INCH SELECTABLE HIGH BAY 1218 LIGHT ENGINE, DOMIC BLACK SHADE, MEDIUM DISTRIBUTION
LIGHT LEVEL 1 - 18,000 LUMENS
Light Source: 6500K CCT, 80 CRI LEDS
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 15481.6 lumens
Efficiency: N/A
Efficacy: 125.6 lumens/watt
Spacing Criteria (0/90/45): 1.11 / 1.11 / 1.11
Luminous Opening: Circular (Dia: 1.23' x H: 0')
CIE Type: Direct

Input Watts (W): 123.3
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1504255

CATALOG NUMBER: PRLX-UHBS2-1218-MV-L8C5-U-A-04-BLAK-PS (6500K_L18_Medium_120V)

Luminous Intensity Polar Plot





TEST NUMBER: P1504255

CATALOG NUMBER: PRLX-UHBS2-1218-MV-L8C5-U-A-04-BLAK-PS (6500K_L18_Medium_120V)

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10			
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0		
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100		
1	113	109	106	104	110	107	105	102	103	101	99	99	98	96	96	95	93	91		
2	106	100	95	91	103	98	94	90	95	91	88	92	89	86	89	87	84	83		
3	99	91	86	81	97	90	85	80	87	83	79	85	81	78	82	79	76	75		
4	93	84	77	72	91	83	76	72	80	75	71	78	74	70	76	72	69	67		
5	87	77	70	65	85	76	69	65	74	68	64	72	67	63	71	66	63	61		
6	81	71	64	59	80	70	63	58	68	62	58	67	62	58	65	61	57	56		
7	76	65	58	53	75	65	58	53	63	57	53	62	57	53	61	56	52	51		
8	72	61	54	49	70	60	53	49	59	53	49	58	52	48	57	52	48	46		
9	68	56	50	45	66	56	49	45	55	49	45	54	48	44	53	48	44	43		
10	64	53	46	41	63	52	46	41	51	45	41	50	45	41	50	45	41	39		

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	95064
5°	95116
10°	94638
15°	93615
20°	90379
25°	86379
30°	80364
35°	70667
40°	56922
45°	43971
50°	34769
55°	16961
60°	6192
65°	2611
70°	753
75°	374
80°	431
85°	493

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 43971 cd/sqm

TEST NUMBER: P1504255

CATALOG NUMBER: PRLX-UHBS2-1218-MV-L8C5-U-A-04-BLAK-PS (6500K_L18_Medium_120V)

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	985.0	6.4
10°-20°	2776.7	17.9
20°-30°	3925.3	25.4
30°-40°	3909.6	25.3
40°-50°	2679.1	17.3
50°-60°	1046.3	6.8
60°-70°	141.1	0.9
70°-80°	13.5	0.1
80°-90°	4.9	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	7687.0	49.7
0°-40°	11596.7	74.9
0°-60°	15322.1	99.0
0°-90°	15481.6	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	15481.6	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	10409	
5°	10375	985
15°	9901	2777
25°	8572	3925
35°	6338	3910
45°	3404	2679
55°	1065	1046
65°	121	141
75°	11	13
85°	5	5
90°	0	

TEST NUMBER: P1504255

CATALOG NUMBER: PRLX-UHBS2-1218-MV-L8C5-U-A-04-BLAK-PS (6500K_L18_Medium_120V)

CANDELA DISTRIBUTION (FULL):

	0°
0°	10409.0
2.5°	10378.5
5°	10375.0
7.5°	10319.8
10°	10204.9
12.5°	10078.2
15°	9901.0
17.5°	9633.5
20°	9299.2
22.5°	8946.1
25°	8571.9
27.5°	8137.8
30°	7620.5
32.5°	7012.8
35°	6338.3
37.5°	5568.7
40°	4774.5
42.5°	4042.5
45°	3404.4
47.5°	2905.8
50°	2447.1
52.5°	1787.8
55°	1065.2
57.5°	506.8
60°	339.0
62.5°	213.5
65°	120.8
67.5°	58.7
70°	28.2
72.5°	12.9
75°	10.6
77.5°	9.4
80°	8.2
82.5°	7.0
85°	4.7
87.5°	2.3
90°	0.0

(END OF REPORT)