

Scaled data based on original data using
LM-79-2024 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: PrentaLux

Report Number: P1504657

Luminaire Tested: PRLX-UHBS2-1218-MV-L8C5-U-B-04-CLER-PS (6500K_L16_Medium_120V)

Issue Date: 7/31/2026

Test Information

Test Method: LM-79-2024
Report Number: P1504657
TEST IS SCALED FROM IESNA LM-79-24 TEST DATA (G2-2602-677-32)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 7/31/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PrentaLux
Catalog Number: PRLX-UHBS2-1218-MV-L8C5-U-B-04-CLER-PS (6500K_L16_Medium_120V)
Description: PrentaLux UHBS2 4-INCH SELECTABLE HIGH BAY 1218 LIGHT ENGINE, CONIC CLEAR SHADE, MEDIUM DISTRIBUTION
LIGHT LEVEL 2 - 16,000 LUMENS
Light Source: 6500K CCT, 80 CRI LEDS
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 15481.5 lumens
Efficiency: N/A
Efficacy: 151.0 lumens/watt
Spacing Criteria (0/90/45): 1.15 / 1.15 / 1.15
Luminous Opening: Ellipsoidal Spheroid (W: 1.26' x L: 1.26' x H: 0.58')
CIE Type: Direct

Input Watts (W): 102.5
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1504657

CATALOG NUMBER: PRLX-UHBS2-1218-MV-L8C5-U-B-04-CLER-PS (6500K_L16_Medium_120V)

Luminous Intensity Polar Plot




TEST NUMBER: P1504657

CATALOG NUMBER: PRLX-UHBS2-1218-MV-L8C5-U-B-04-CLER-PS (6500K_L16_Medium_120V)

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10			
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0		
RCR																				
0	118	118	118	118	115	115	115	115	109	109	109	104	104	104	99	99	99	97		
1	111	107	104	101	108	105	102	99	100	98	96	96	94	92	92	90	89	87		
2	103	97	92	88	101	95	90	86	91	87	84	88	84	82	84	82	79	77		
3	96	88	82	77	94	86	80	76	83	78	74	80	76	73	77	74	71	69		
4	90	80	73	68	87	79	72	67	76	70	66	73	69	65	71	67	64	62		
5	84	73	66	60	82	72	65	60	70	64	59	68	62	58	66	61	57	56		
6	78	67	60	54	76	66	59	54	64	58	53	62	57	53	61	56	52	50		
7	73	62	54	49	71	61	54	49	59	53	48	58	52	48	56	51	47	46		
8	69	57	50	45	67	56	49	44	55	49	44	53	48	44	52	47	43	42		
9	65	53	46	41	63	52	45	41	51	45	40	50	44	40	49	43	40	38		
10	61	49	42	38	60	49	42	37	47	41	37	46	41	37	45	40	37	35		

AVERAGE LUMINANCE (cd/sqm):



MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: -
Vertical Angle: -
Luminance: -

TEST NUMBER: P1504657

CATALOG NUMBER: PRLX-UHBS2-1218-MV-L8C5-U-B-04-CLER-PS (6500K_L16_Medium_120V)

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	847.3	5.5
10°-20°	2414.5	15.6
20°-30°	3473.1	22.4
30°-40°	3590.8	23.2
40°-50°	2591.2	16.7
50°-60°	1277.7	8.3
60°-70°	544.1	3.5
70°-80°	182.4	1.2
80°-90°	92.1	0.6
90°-100°	153.0	1.0
100°-110°	157.0	1.0
110°-120°	75.5	0.5
120°-130°	29.2	0.2
130°-140°	19.2	0.1
140°-150°	15.5	0.1
150°-160°	11.1	0.1
160°-170°	6.0	0.0
170°-180°	1.7	0.0
0°-30°	6735.0	43.5
0°-40°	10325.8	66.7
0°-60°	14194.7	91.7
0°-90°	15013.2	97.0
90°-120°	385.6	2.5
90°-150°	449.5	2.9
90°-180°	468.0	3.0
0°-180°	15481.5	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	8927	
5°	8911	847
15°	8597	2414
25°	7577	3473
35°	5810	3591
45°	3312	2591
55°	1355	1278
65°	562	544
75°	153	182
85°	77	68
90°	94	53
95°	145	124
105°	152	157
115°	74	76
125°	30	29
135°	24	19
145°	24	16
155°	24	11
165°	21	6
175°	17	2
180°	18	

TEST NUMBER: P1504657

CATALOG NUMBER: PRLX-UHBS2-1218-MV-L8C5-U-B-04-CLER-PS (6500K_L16_Medium_120V)

CANDELA DISTRIBUTION (FULL):

0°	
0°	8927.2
2.5°	8908.0
5°	8911.1
7.5°	8880.7
10°	8805.8
12.5°	8717.7
15°	8597.2
17.5°	8405.9
20°	8154.8
22.5°	7881.5
25°	7576.7
27.5°	7227.4
30°	6813.4
32.5°	6342.6
35°	5810.1
37.5°	5214.8
40°	4533.5
42.5°	3898.7
45°	3312.5
47.5°	2808.4
50°	2427.7
52.5°	1907.3
55°	1354.6
57.5°	907.1
60°	765.4
62.5°	664.1
65°	561.9
67.5°	438.4
70°	313.8
72.5°	212.6
75°	152.9
77.5°	121.5
80°	97.2
82.5°	83.0
85°	76.9
87.5°	82.0
90°	94.2
92.5°	117.4
95°	144.8
97.5°	166.0
100°	172.1
102.5°	166.0
105°	151.9
107.5°	132.6
110°	112.4

TEST NUMBER: P1504657

CATALOG NUMBER: PRLX-UHBS2-1218-MV-L8C5-U-B-04-CLER-PS (6500K_L16_Medium_120V)

CANDELA DISTRIBUTION (continued):

	0°
112.5°	92.1
115°	73.9
117.5°	57.7
120°	45.6
122.5°	36.4
125°	30.4
127.5°	27.3
130°	25.3
132.5°	24.3
135°	24.3
137.5°	25.3
140°	25.3
142.5°	25.3
145°	24.3
147.5°	24.3
150°	24.3
152.5°	24.3
155°	24.3
157.5°	23.3
160°	23.3
162.5°	22.3
165°	21.3
167.5°	19.2
170°	18.2
172.5°	17.2
175°	17.2
177.5°	18.2
180°	18.2

(END OF REPORT)