

Scaled data based on original data using
LM-79-2024 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: PrentaLux

Report Number: P1504942

Luminaire Tested: PRLX-UHBS2-2436-MV-L8C5-U-A-04-BLAK-PS (3500K_L24_Medium_120V)

Issue Date: 7/31/2026

Test Information

Test Method: LM-79-2024
Report Number: P1504942
TEST IS SCALED FROM IESNA LM-79-24 TEST DATA (G2-2602-677-80)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 7/31/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PrentaLux
Catalog Number: PRLX-UHBS2-2436-MV-L8C5-U-A-04-BLAK-PS (3500K_L24_Medium_120V)
Description: PrentaLux UHBS2 4-INCH SELECTABLE HIGH BAY 2436 LIGHT ENGINE, DOMIC BLACK SHADE, MEDIUM DISTRIBUTION
LIGHT LEVEL 1 - 24,000 LUMENS
Light Source:
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 21882.7 lumens
Efficiency: N/A
Efficacy: 138.9 lumens/watt
Spacing Criteria (0/90/45): 1.18 / 1.18 / 1.15
Luminous Opening: Circular (Dia: 1.37' x H: 0')
CIE Type: Direct

Input Watts (W): 157.5
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1504942

CATALOG NUMBER: PRLX-UHBS2-2436-MV-L8C5-U-A-04-BLAK-PS (3500K_L24_Medium_120V)

Luminous Intensity Polar Plot





TEST NUMBER: P1504942

CATALOG NUMBER: PRLX-UHBS2-2436-MV-L8C5-U-A-04-BLAK-PS (3500K_L24_Medium_120V)

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20
RC	80					70					50					30					0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0			
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			
1	112	109	106	104	110	107	104	102	103	101	99	99	97	96	96	94	93	91			
2	105	100	95	91	103	98	93	90	95	91	88	91	88	86	89	86	84	82			
3	99	91	85	80	96	89	84	79	87	82	78	84	80	77	82	79	76	74			
4	92	83	76	71	90	82	76	71	80	74	70	77	73	69	75	72	68	67			
5	86	76	69	64	84	75	69	64	73	67	63	71	66	62	70	65	62	60			
6	81	70	63	58	79	69	62	57	68	61	57	66	61	57	65	60	56	54			
7	76	65	57	52	74	64	57	52	62	56	52	61	56	52	60	55	51	50			
8	71	60	53	48	70	59	52	48	58	52	47	57	51	47	56	51	47	45			
9	67	55	48	44	66	55	48	44	54	48	43	53	47	43	52	47	43	42			
10	63	52	45	40	62	51	45	40	50	44	40	49	44	40	49	43	40	38			

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	100318
5°	100255
10°	99719
15°	99296
20°	98314
25°	96531
30°	91930
35°	82656
40°	66313
45°	50746
50°	38628
55°	24380
60°	7872
65°	3835
70°	1034
75°	400
80°	490
85°	556

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 50746 cd/sqm

TEST NUMBER: P1504942

CATALOG NUMBER: PRLX-UHBS2-2436-MV-L8C5-U-A-04-BLAK-PS (3500K_L24_Medium_120V)

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	1292.0	5.9
10°-20°	3684.1	16.8
20°-30°	5460.2	25.0
30°-40°	5656.3	25.8
40°-50°	3828.7	17.5
50°-60°	1694.0	7.7
60°-70°	239.5	1.1
70°-80°	21.2	0.1
80°-90°	6.7	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	10436.2	47.7
0°-40°	16092.6	73.5
0°-60°	21615.2	98.8
0°-90°	21882.7	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	21882.7	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	13672	
5°	13611	###
15°	13071	3684
25°	11923	5460
35°	9228	5656
45°	4890	3829
55°	1906	1694
65°	221	239
75°	14	21
85°	7	7
90°	0	

TEST NUMBER: P1504942

CATALOG NUMBER: PRLX-UHBS2-2436-MV-L8C5-U-A-04-BLAK-PS (3500K_L24_Medium_120V)

CANDELA DISTRIBUTION (FULL):

0°	
0°	13671.8
2.5°	13639.4
5°	13611.2
7.5°	13525.6
10°	13383.6
12.5°	13229.2
15°	13071.4
17.5°	12856.3
20°	12590.6
22.5°	12290.8
25°	11923.0
27.5°	11452.1
30°	10850.1
32.5°	10126.0
35°	9227.5
37.5°	8086.5
40°	6923.1
42.5°	5850.2
45°	4890.3
47.5°	4074.8
50°	3383.9
52.5°	2655.6
55°	1905.8
57.5°	1142.6
60°	536.4
62.5°	349.6
65°	220.9
67.5°	114.6
70°	48.2
72.5°	23.3
75°	14.1
77.5°	13.3
80°	11.6
82.5°	9.1
85°	6.6
87.5°	3.3
90°	0.0

(END OF REPORT)