

Scaled data based on original data using
LM-79-2024 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: PrentaLux

Report Number: P1505125

Luminaire Tested: PRLX-UHBS2-2436-MV-L8C5-U-A-06-BLAK-PS (3500K_L32_Medium_120V)

Issue Date: 7/31/2026

Test Information

Test Method: LM-79-2024
Report Number: P1505125
TEST IS SCALED FROM IESNA LM-79-24 TEST DATA (G2-2602-677-104)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 7/31/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PrentaLux
Catalog Number: PRLX-UHBS2-2436-MV-L8C5-U-A-06-BLAK-PS (3500K_L32_Medium_120V)
Description: PrentaLux UHBS2 6-INCH SELECTABLE HIGH BAY 2436 LIGHT ENGINE, DOMIC BLACK SHADE, MEDIUM DISTRIBUTION
LIGHT LEVEL 2 - 32,000 LUMENS
Light Source:
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 23240.5 lumens
Efficiency: N/A
Efficacy: 118.3 lumens/watt
Spacing Criteria (0/90/45): 1.21 / 1.21 / 1.14
Luminous Opening: Circular (Dia: 1.43' x H: 0')
CIE Type: Direct

Input Watts (W): 196.5
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1505125

CATALOG NUMBER: PRLX-UHBS2-2436-MV-L8C5-U-A-06-BLAK-PS (3500K_L32_Medium_120V)

Luminous Intensity Polar Plot





TEST NUMBER: P1505125

CATALOG NUMBER: PRLX-UHBS2-2436-MV-L8C5-U-A-06-BLAK-PS (3500K_L32_Medium_120V)

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20				
RC	80					70					50					30					10				
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10		
RCR																									
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100							
1	113	110	107	104	110	107	105	103	103	101	100	100	98	97	96	95	94	92							
2	106	101	96	92	104	99	95	91	96	92	89	93	90	87	90	88	85	84							
3	100	92	87	82	98	91	86	82	88	84	80	86	82	79	84	80	78	76							
4	94	85	79	74	92	84	78	73	82	77	73	80	75	72	78	74	71	69							
5	88	78	72	67	86	77	71	66	76	70	66	74	69	65	72	68	65	63							
6	83	72	66	61	81	72	65	60	70	64	60	69	63	60	67	63	59	58							
7	78	67	60	55	76	66	60	55	65	59	55	64	58	55	63	58	54	53							
8	73	62	55	51	72	62	55	51	60	55	50	59	54	50	58	54	50	48							
9	69	58	51	47	68	57	51	47	56	51	46	55	50	46	55	50	46	45							
10	65	54	48	43	64	54	47	43	53	47	43	52	47	43	51	46	43	41							

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	104960
5°	104812
10°	104351
15°	104091
20°	103483
25°	103018
30°	100800
35°	86828
40°	66096
45°	43963
50°	23527
55°	6699
60°	2989
65°	931
70°	702
75°	773
80°	845
85°	918

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 43963 cd/sqm

TEST NUMBER: P1505125

CATALOG NUMBER: PRLX-UHBS2-2436-MV-L8C5-U-A-06-BLAK-PS (3500K_L32_Medium_120V)

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	1486.3	6.4
10°-20°	4250.2	18.3
20°-30°	6428.7	27.7
30°-40°	6559.8	28.2
40°-50°	3636.5	15.6
50°-60°	751.7	3.2
60°-70°	83.3	0.4
70°-80°	31.4	0.1
80°-90°	12.5	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	12165.2	52.3
0°-40°	18725.1	80.6
0°-60°	23113.3	99.5
0°-90°	23240.5	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	23240.5	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	15734	
5°	15652	###
15°	15072	4250
25°	13996	6429
35°	10662	6560
45°	4660	3636
55°	576	752
65°	59	83
75°	30	31
85°	12	13
90°	0	

TEST NUMBER: P1505125

CATALOG NUMBER: PRLX-UHBS2-2436-MV-L8C5-U-A-06-BLAK-PS (3500K_L32_Medium_120V)

CANDELA DISTRIBUTION (FULL):

0°	
0°	15734
2.5°	15683
5°	15652
7.5°	15561
10°	15405
12.5°	15246
15°	15072
17.5°	14834
20°	14577
22.5°	14301
25°	13996
27.5°	13598
30°	13086
32.5°	12006
35°	10662
37.5°	9195
40°	7590
42.5°	6054
45°	4660
47.5°	3429
50°	2267
52.5°	1233
55°	576
57.5°	371
60°	224
62.5°	111
65°	59
67.5°	40
70°	36
72.5°	33
75°	30
77.5°	27
80°	22
82.5°	17
85°	12
87.5°	6
90°	0

(END OF REPORT)