

Scaled data based on original data using
LM-79-2024 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: PrentaLux

Report Number: P1505082

Luminaire Tested: PRLX-UHBS2-2436-MV-L8C5-U-A-04-WHGL-PS (3500K_L32_Wide_120V)

Issue Date: 7/31/2026

Test Information

Test Method: LM-79-2024
Report Number: P1505082
TEST IS SCALED FROM IESNA LM-79-24 TEST DATA (G2-2602-677-87)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 7/31/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PrentaLux
Catalog Number: PRLX-UHBS2-2436-MV-L8C5-U-A-04-WHGL-PS (3500K_L32_Wide_120V)
Description: PrentaLux UHBS2 4-INCH SELECTABLE HIGH BAY 2436 LIGHT ENGINE, DOMIC WHITE SHADE, WIDE DISTRIBUTION
LIGHT LEVEL 2 - 32,000 LUMENS
Light Source:
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 30055.4 lumens
Efficiency: N/A
Efficacy: 153.2 lumens/watt
Spacing Criteria (0/90/45): 1.32 / 1.32 / 1.31
Luminous Opening: Circular (Dia: 1.37' x H: 0')
CIE Type: Direct

Input Watts (W): 196.2
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1505082

CATALOG NUMBER: PRLX-UHBS2-2436-MV-L8C5-U-A-04-WHGL-PS (3500K_L32_Wide_120V)

Luminous Intensity Polar Plot





TEST NUMBER: P1505082

CATALOG NUMBER: PRLX-UHBS2-2436-MV-L8C5-U-A-04-WHGL-PS (3500K_L32_Wide_120V)

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10			
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0		
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100		
1	111	108	104	101	109	105	102	100	101	99	97	97	95	94	94	92	91	89		
2	104	97	92	87	101	95	90	86	92	88	84	89	85	82	86	83	81	79		
3	96	88	81	76	94	86	80	75	83	78	74	81	76	73	78	75	71	70		
4	89	79	72	67	87	78	71	66	76	70	65	74	69	64	72	67	64	62		
5	83	72	65	59	81	71	64	59	69	63	58	67	62	58	66	61	57	55		
6	77	66	58	53	76	65	58	52	63	57	52	62	56	52	60	55	51	49		
7	72	60	53	47	71	60	52	47	58	52	47	57	51	47	56	50	46	45		
8	68	56	48	43	66	55	48	43	54	47	42	53	47	42	51	46	42	40		
9	63	51	44	39	62	51	44	39	50	43	39	49	43	38	48	42	38	37		
10	60	48	40	36	58	47	40	36	46	40	35	45	39	35	44	39	35	34		

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	108428
5°	108710
10°	109072
15°	110088
20°	110647
25°	111468
30°	112213
35°	111808
40°	102366
45°	83317
50°	59371
55°	38583
60°	18153
65°	13490
70°	13280
75°	15678
80°	19395
85°	24078

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 83317 cd/sqm

TEST NUMBER: P1505082

CATALOG NUMBER: PRLX-UHBS2-2436-MV-L8C5-U-A-04-WHGL-PS (3500K_L32_Wide_120V)

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	1404.9	4.7
10°-20°	4090.7	13.6
20°-30°	6349.7	21.1
30°-40°	7669.8	25.5
40°-50°	6134.9	20.4
50°-60°	2727.4	9.1
60°-70°	812.4	2.7
70°-80°	579.4	1.9
80°-90°	286.2	1.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	11845.3	39.4
0°-40°	19515.1	64.9
0°-60°	28377.3	94.4
0°-90°	30055.4	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	30055.4	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	14777	
5°	14759	###
15°	14492	4091
25°	13768	6350
35°	12482	7670
45°	8029	6135
55°	3016	2727
65°	777	812
75°	553	579
85°	286	286
90°	0	

TEST NUMBER: P1505082

CATALOG NUMBER: PRLX-UHBS2-2436-MV-L8C5-U-A-04-WHGL-PS (3500K_L32_Wide_120V)

CANDELA DISTRIBUTION (FULL):

	0°
0°	14777
2.5°	14761
5°	14759
7.5°	14718
10°	14639
12.5°	14567
15°	14492
17.5°	14352
20°	14170
22.5°	13971
25°	13768
27.5°	13533
30°	13244
32.5°	12906
35°	12482
37.5°	11679
40°	10687
42.5°	9429
45°	8029
47.5°	6588
50°	5201
52.5°	4019
55°	3016
57.5°	2057
60°	1237
62.5°	903
65°	777
67.5°	680
70°	619
72.5°	585
75°	553
77.5°	516
80°	459
82.5°	385
85°	286
87.5°	151
90°	0

(END OF REPORT)