

Scaled data based on original data using
LM-79-2024 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: PrentaLux

Report Number: P1505335

Luminaire Tested: PRLX-UHBS2-2436-MV-L8C5-U-B-04-BLAK-PS (6500K_L36_Medium_120V)

Issue Date: 7/31/2026

Test Information

Test Method: LM-79-2024
Report Number: P1505335
TEST IS SCALED FROM IESNA LM-79-24 TEST DATA (G2-2602-677-92)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 7/31/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PrentaLux
Catalog Number: PRLX-UHBS2-2436-MV-L8C5-U-B-04-BLAK-PS (6500K_L36_Medium_120V)
Description: PrentaLux UHBS2 4-INCH SELECTABLE HIGH BAY 2436 LIGHT ENGINE, CONIC BLACK SHADE, MEDIUM DISTRIBUTION
LIGHT LEVEL 1 - 36,000 LUMENS
Light Source:
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 31090.6 lumens
Efficiency: N/A
Efficacy: 129.8 lumens/watt
Spacing Criteria (0/90/45): 1.18 / 1.18 / 1.15
Luminous Opening: Circular (Dia: 1.38' x H: 0')
CIE Type: Direct

Input Watts (W): 239.6
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1505335

CATALOG NUMBER: PRLX-UHBS2-2436-MV-L8C5-U-B-04-BLAK-PS (6500K_L36_Medium_120V)

Luminous Intensity Polar Plot





TEST NUMBER: P1505335

CATALOG NUMBER: PRLX-UHBS2-2436-MV-L8C5-U-B-04-BLAK-PS (6500K_L36_Medium_120V)

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10			
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0		
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100		
1	112	109	106	104	110	107	104	102	103	101	99	99	97	96	96	94	93	91		
2	105	100	95	91	103	98	93	90	94	91	88	91	88	86	89	86	84	82		
3	99	91	85	80	96	89	84	79	87	82	78	84	80	77	82	78	76	74		
4	92	83	76	71	90	82	76	71	80	74	70	77	73	69	75	71	68	66		
5	86	76	69	64	84	75	68	64	73	67	63	71	66	62	70	65	62	60		
6	81	70	63	58	79	69	62	57	67	61	57	66	61	56	64	60	56	54		
7	76	64	57	52	74	64	57	52	62	56	52	61	56	51	60	55	51	49		
8	71	60	53	48	70	59	52	48	58	52	47	57	51	47	56	51	47	45		
9	67	55	48	44	65	55	48	44	54	48	43	53	47	43	52	47	43	41		
10	63	52	45	40	62	51	45	40	50	44	40	49	44	40	49	43	40	38		

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	138683
5°	138741
10°	138147
15°	137546
20°	136090
25°	133502
30°	127067
35°	113932
40°	91532
45°	70360
50°	53955
55°	34863
60°	11279
65°	5460
70°	1472
75°	584
80°	676
85°	772

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 70360 cd/sqm

TEST NUMBER: P1505335

CATALOG NUMBER: PRLX-UHBS2-2436-MV-L8C5-U-B-04-BLAK-PS (6500K_L36_Medium_120V)

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	1832.5	5.9
10°-20°	5228.0	16.8
20°-30°	7736.6	24.9
30°-40°	7995.0	25.7
40°-50°	5439.5	17.5
50°-60°	2466.8	7.9
60°-70°	350.8	1.1
70°-80°	31.4	0.1
80°-90°	9.9	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	14797.1	47.6
0°-40°	22792.1	73.3
0°-60°	30698.4	98.7
0°-90°	31090.6	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	31090.6	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	19364	
5°	19298	###
15°	18551	5228
25°	16894	7737
35°	13031	7995
45°	6947	5439
55°	2792	2467
65°	322	351
75°	21	31
85°	9	10
90°	0	

TEST NUMBER: P1505335

CATALOG NUMBER: PRLX-UHBS2-2436-MV-L8C5-U-B-04-BLAK-PS (6500K_L36_Medium_120V)

CANDELA DISTRIBUTION (FULL):

	0°
0°	19364.0
2.5°	19327.7
5°	19298.4
7.5°	19190.6
10°	18996.1
12.5°	18782.9
15°	18550.9
17.5°	18240.4
20°	17856.1
22.5°	17421.4
25°	16894.1
27.5°	16219.3
30°	15365.1
32.5°	14325.9
35°	13031.2
37.5°	11414.3
40°	9790.4
42.5°	8289.5
45°	6946.8
47.5°	5812.6
50°	4842.5
52.5°	3832.5
55°	2792.1
57.5°	1716.5
60°	787.4
62.5°	512.0
65°	322.2
67.5°	168.7
70°	70.3
72.5°	35.1
75°	21.1
77.5°	19.9
80°	16.4
82.5°	12.9
85°	9.4
87.5°	5.9
90°	0.0

(END OF REPORT)